



Gippsland
Water

Annual Report on Drinking Water Quality 2018–19




Our Service Area

We acknowledge Traditional Custodians of the land on which we live and work. We pay respect to Elders past and present. We are committed to working respectfully to honour their ongoing cultural and spiritual connections to this country. We recognise the role and value of culture in our work and community.

We cover areas of two traditional landowner groups:

- Gunaikurnai Land and Waters Aboriginal Corporation
- Bunurong Land Council Aboriginal Corporation



Legend

- Latrobe River catchment boundary
- Gippsland Water operating area



CONTENTS

1.	INTRODUCTION	7
1.1	CHARACTERISATION OF THE SYSTEM.....	7
1.2	WATER QUALITY ACTIVITIES	8
2.	DRINKING WATER QUALITY MANAGEMENT FRAMEWORK	10
3	DRINKING WATER QUALITY POLICY	15
4	DRINKING WATER SUPPLY SYSTEMS	17
4.1	<i>Source of water</i>	17
4.2	WATER QUALITY MANAGEMENT SYSTEM.....	23
4.2.1	<i>Hazard and risk identification</i>	23
4.2.2	<i>Control measures</i>	23
4.2.3	<i>Verification and monitoring</i>	24
4.2.4	<i>System auditing</i>	24
4.3	WATER TREATMENT PROCESSES.....	25
4.3.1	<i>Coagulation/flocculation</i>	25
4.3.2	<i>Clarification/sedimentation</i>	25
4.3.3	<i>Membrane filtration</i>	25
4.3.4	<i>Filtration</i>	25
4.3.5	<i>Sequestration</i>	26
4.3.6	<i>Disinfection</i>	26
4.3.7	<i>Added substances</i>	27
4.3.8	<i>Distribution</i>	28
5	SYSTEM ISSUES FOR 2018-19	29
6	QUALITY OF DRINKING WATER 2018-19	30
6.1	WATER QUALITY STANDARDS (SDWR 2015)	30
6.2	WATER QUALITY STANDARDS	31
6.3	EMERGENCY/INCIDENT MANAGEMENT	31
6.4	INCIDENT AND POTENTIAL WATER QUALITY EVENTS.....	32
6.5	EMERGENCIES AND WATER QUALITY EVENTS.....	32
6.6	OTHER EVENTS NOT REPORTABLE	33
7	COMPLAINTS	34
7.1	WATER QUALITY COMPLAINTS.....	34
7.2	A SUMMARY OF THE CUSTOMER COMPLAINT PROCESS.....	37
8	RISK MANAGEMENT PLAN AUDIT	41
9	WATER QUALITY RESULTS FOR 2018-19	43
9.1	ESCHERICHIA COLI (E. COLI).....	43
9.1.1	<i>E. coli results</i>	43
9.1.2	<i>Actions taken in relation to non-compliance</i>	45
9.2	CHLORINE BASED DISINFECTION BY-PRODUCT CHEMICALS	46
9.2.1	<i>Trihalomethanes (THM) results</i>	46
9.2.2	<i>Actions taken in relation to non-compliance</i>	47
9.3	TURBIDITY	48
9.3.1	<i>Turbidity results</i>	48
9.3.2	<i>Actions taken in relation to non-compliance</i>	49
9.4	FLUORIDE.....	50
9.4.1	<i>Fluoride results</i>	50
9.4.2	<i>Actions taken in relation to non-compliance</i>	51
9.4.3	<i>Fluoride dosing systems performance and maintenance 2018-19</i>	51
9.5	WATER TREATMENT PROJECTS AND PROGRAMS UNDERTAKEN.....	53
9.6	CATCHMENT PROJECTS AND PROGRAMS UNDERTAKEN	59
9.7	OTHER ALGAE, PATHOGEN, CHEMICAL OR SUBSTANCE NOT SPECIFIED THAT MAY POSE A RISK TO HUMAN HEALTH.....	66

9.7.1	Overall results	66
9.7.2	Manganese	68
9.7.3	Actions taken in relation to non-compliance	68
9.7.4	Lead	69
9.7.5	Actions taken in relation to non-compliance	69
9.7.6	Copper	70
9.7.7	Actions taken in relation to non-compliance	70
9.8	AESTHETICS	71
9.8.1	pH results	71
9.8.2	Actions taken in relation to non-compliance	71
9.8.3	Iron results	73
9.8.4	Actions taken in relation to non-compliance	73
9.9	ANALYSIS OF RESULTS	74
10	UNDERTAKINGS UNDER SECTION 30 OF THE SDWA	76
11	EXEMPTIONS UNDER SECTION 20 OF THE SDWA	76
12	VARIATION IN AESTHETIC STANDARDS	76
13	REGULATED WATER	76
14	GLOSSARY OF TERMS	76
15	FURTHER INFORMATION	78
16	REFERENCES	78
	APPENDIX 1: RAW WATER MONITORING	80
	APPENDIX 2: SAFE DRINKING WATER ACT AUDIT CERTIFICATE OF COMPLIANCE	88

TABLES

TABLE 1: GIPPSLAND WATER LOCALITY WATER SOURCE AND WATER TREATMENT PROCESS	17
TABLE 2: SUMMARY OF THE SAFE DRINKING WATER REGULATIONS 2015 (SCHEDULE 2):	31
TABLE 3: SUMMARY OF NOTIFICATIONS UNDER SECTION 18	32
TABLE 4: SUMMARY OF INCIDENTS AND ACTIONS TAKEN UNDER SECTION 22	33
TABLE 5: WATER QUALITY COMPLAINTS PER 100 CUSTOMERS SUPPLIED	34
TABLE 6: CUSTOMER COMPLAINTS SUMMARY FOR EACH SAMPLING LOCALITY 2018-19	37
TABLE 7: RISK MANAGEMENT PLAN COMPLETED OPPORTUNITY FOR IMPROVEMENTS	42
TABLE 8: <i>E. COLI</i> DETECTIONS FOR LOCALITIES 2018-19	43
TABLE 9: <i>E. COLI</i> RESULTS FOR ALL LOCALITIES FOR 2018-19	43
TABLE 10: COMPARISON OF <i>E. COLI</i> RESULTS FOR PREVIOUS YEARS (2016 - 2019)	44
TABLE 11: TRIHALOMETHANES RESULTS FOR ALL LOCALITIES FOR 2018-19	46
TABLE 12: COMPARISON OF TRIHALOMETHANE (THM) RESULTS FOR PREVIOUS YEARS (2016 - 2019)	47
TABLE 13: TURBIDITY RESULTS FOR ALL LOCALITIES IN 2018-19	48
TABLE 14: COMPARISON OF TURBIDITY RESULTS FOR PREVIOUS YEARS (2016 - 2019)	49
TABLE 15: FLUORIDE RESULTS FOR ALL FLUORIDATED LOCALITIES IN 2018-19	50
TABLE 16: COMPARISON OF FLUORIDE RESULTS FOR PREVIOUS YEARS (2016- 2019)	51
TABLE 17: GIPPSLAND WATER LOCALITY WATER SOURCE AND ACTIVITIES UNDERTAKEN	60
TABLE 18: OTHER SAMPLED PARAMETER RESULTS FOR ALL LOCALITIES IN 2018-19	66
TABLE 19: ROUTINE BGA MONITORING FOR RAW WATER SUPPLIES IN 2018-19 (SAMPLES PER MONTH COLLECTED)	67
TABLE 20: MANGANESE RESULTS FOR ALL LOCALITIES IN 2018-19	68

TABLE 21: LEAD RESULTS FOR ALL LOCALITIES IN 2018-19	69
TABLE 22: COPPER RESULTS FOR ALL LOCALITIES IN 2018-19	70
TABLE 23: PH RESULTS FOR ALL LOCALITIES IN 2018-19	71
TABLE 24: IRON RESULTS FOR ALL LOCALITIES IN 2018-19	73
TABLE 25: COMPLIANCE BY LOCALITY AND POPULATION	74
TABLE 26: GLOSSARY OF TERMS	76

FIGURES

FIGURE 1: WSAA WATER SAFETY ASSESSMENT PROCESS	14
FIGURE 2: LAKE GLENMAGGIE MAY 2019	29
FIGURE 3: TOTAL CUSTOMER COMPLAINTS FOR 2004-05 TO 2018-19	35
FIGURE 4: CUSTOMER COMPLAINTS PER 100 CUSTOMERS FOR 2018-19	36
FIGURE 5: CUSTOMER WATER QUALITY COMPLAINTS BY TYPE 2018-19	36
FIGURE 6: WATER QUALITY COMPLAINTS RESOLUTION PROCEDURE	39
FIGURE 7: DISINFECTION DOSING LANCE INNOVATION – DISINFECTION SYSTEM UPGRADE	53
FIGURE 8: MAFFRA, MIRBOO NORTH AND WARRAGUL WATER TREATMENT PLANT – STREAMING CURRENT CONTROL UNIT	54
FIGURE 9: MOE WATER TREATMENT PLANT – TRANSFER PIPE UPGRADE	54
FIGURE 10: HEYFIELD WATER TREATMENT PLANT – CHEMICAL DOSING SYSTEM	55
FIGURE 11: MORWELL WATER SUPPLY LOCALITY RIDGE RESERVOIR PROJECT – CHEMICAL DOSING SYSTEM	55
FIGURE 12: MOE WATER TREATMENT PLANT – OFF SPECIFICATION WATER BASIN CLEAN AND REINSTATEMENT	56
FIGURE 13: TRARALGON WATER TREATMENT PLANT – FILTER UPGRADE	56
FIGURE 14: WATER QUALITY – WATER INFORMATION MANAGEMENT SYSTEM	57
FIGURE 15: WATER QUALITY – MONITORING INSTRUMENTATION UPGRADES	58
FIGURE 16: MIRBOO NORTH WEIR – DESILT CLEAN-UP ACTIVITIES	59

This page intentionally left blank

1. INTRODUCTION

1.1 CHARACTERISATION OF THE SYSTEM

- We are the Central Gippsland Region Water Corporation, and trade as Gippsland Water. We are a regional water corporation in Victoria established under the *Water Act 1989* and constituted on 21 December 1994.

With 306 operational, engineering, financial, environmental and administrative employees, we are a major local employer for the region serving a population base of 147,000 people.

We deliver water to 70,906 customers and wastewater services to 63,600 customers in 43 towns. Our customers include major industries, some of which are of state and national significance.

These towns are grouped into 35 localities for the purposes of monitoring and reporting in accordance with the *Safe Drinking Water Regulations 2015 (SDWR)*.

Our service area spans from Drouin in the west, to Loch Sport in the east, from Briagolong in the north, to Mirboo North in the south. This covers approximately 5,000 square kilometres in the municipalities of the Baw Baw Shire, Latrobe City, South Gippsland Shire, and Wellington Shire.

The way we treat water depends on where it is sourced. We take water from 13 different sources including aquifers, rivers, creeks and reservoirs. Our largest storage is Moondarra Reservoir, south of Erica, with a capacity of 30,458ML. We also take water from storages managed by Southern Rural Water (Blue Rock Dam and Lake Glenmaggie) and Melbourne Water (Tarago Reservoir).

Gippsland Water is the second largest regional water corporation in Victoria in terms of revenue earned and is the largest in terms of the total volume of water supplied and wastewater collected. We own and maintain a \$1 billion infrastructure network which includes:

- More than 2,000 kilometres of water mains, 65 treated water storages, and 48 pump stations.
- More than 1,700 kilometres of sewer mains and 199 sewer pump stations.
- 15 water treatment plants.
- 14 wastewater treatment plants including the Gippsland Water Factory.
- Two ocean outfalls (McGaurans Beach and Delray Beach).
- Soil and Organic Recycling Facility; and
- Agribusiness

Gippsland Water is committed to providing responsible asset management, quality management, incident management and operational audit of the reticulated urban water supply system to ensure that customer service levels are achieved according to its Customer Charter targets and the *Safe Drinking Water Act 2003 (SDWA)*.

A major objective for the corporation is to achieve and maintain community confidence in the safety, reliability and quality of their water supply.

To ensure customers are provided with safe drinking water, Gippsland Water maintains a '*risk based*' drinking water quality management system, which covers the entire water supply system from the catchment to customers' taps. The system entails:

- detailed water quality risk identification processes;
- audited control measures to manage risks;
- continuous improvement project to increase system capability, manage risk and improve customer experiences; and
- verification systems, including an independent water quality monitoring program.

1.2 WATER QUALITY ACTIVITIES

In 2018-19, we made many improvements to ensure our customers' water quality was maintained, including:

- Finalising an Integrated Catchment Land Use Options Strategy for the Moondarra Catchment to protect water quality;
- Commencing a review of Catchment Sanitary Surveys (including spatial mapping) for our catchments;
- Upgrading some of our secondary disinfection systems to maintain water quality safety as part of our rolling upgrade program;
- Upgrading process controls for improved water treatment plant operation;
- Upgrading activated carbon dosing at the Coongulla Water Treatment Plant to improve taste and odour;
- Enhancing our Water Information Management System (WIMS) enabling external data migration and transition to a digital system. This continues to improve our understanding of and access to field, water treatment plant, and process and compliance data;
- Consolidated the 'Five Cs for Protecting Water Quality' initiative for unplanned water main breaks. Our teams refer to the five Cs to ensure: Clean pipes – check before installing; Clearance – stop contaminated water running into pipes; Chlorination – flush after repair; Cleanliness – clean tools and separate from contamination; and Clothing – wear appropriate clothing; and
- Delivering air scouring works to maintain water quality in our reticulation networks by cleaning pipes.

Our Vision and Values

VISION

We take pride in partnering with the community in providing quality water and waste services so we can enjoy a healthy and sustainable Gippsland for generations to come

Safety and wellbeing

Customer focussed

Innovation

Accountability

Collaboration

Integrity and respect

Our Strategic Priorities

OUR STRATEGIC PRIORITIES FOCUS ON THE FOLLOWING SIX THEMES:

Each of these strategic themes has a five year destination statement, strategic objectives to focus our attention and resources, and a set of strategic actions to deliver on those objectives.



Healthy people, healthy environment
We are a leader in safety, public health and the environment to support a healthier community.



Enabling our people
Through a constructive culture, we are an engaged and empowered workforce capable of delivering on our priorities.



Strengthening relationships
On behalf of our community we help shape the health and prosperity of the Gippsland region.



Customer focussed
We learn from our customers and deliver on our promises.



Business sustainability
We invest strategically and make evidence-based decisions that deliver value for money to secure our future.



Clever thinking
We foster innovation and empower people to find and deliver efficiencies that transform our business.

2. DRINKING WATER QUALITY MANAGEMENT FRAMEWORK

The regulatory environment in which Gippsland Water operates is to provide safe drinking water at **all** times. Safe drinking water is water that does not cause illness in those who consume it. To achieve this, the water must be free of pathogens and harmful chemicals.

Guidance regarding the structure of this report has been provided by the Department of Health and Human Services (DHHS) in accordance with the *Safe Drinking Water Act 2003* (Section 26) and the current Water Quality Annual Report Guidance, June 2019.

Drinking water supplied by Gippsland Water must meet the obligations under the *Safe Drinking Water Act 2003* and the *Safe Drinking Water Regulations 2015*. The Australian Drinking Water Guidelines 2011 (ADWG) are used as a benchmark for safe drinking water. The guidelines provide a framework for good management of drinking water supplies that if implemented, will ensure safety at the point of use

The ADWG include two types of guideline values:

- a health related guideline value, which is the concentration or measure of a water quality characteristic that, based on present knowledge, does not result in any significant risk to health of the consumer over a lifetime of consumption; and
- an aesthetic guideline value, which is the concentration or measure of a water quality characteristic that is associated with acceptability of water to the consumer, such as appearance, taste and odour.

The regulatory environment that provides guidance in the production of safe drinking water consists of:

- ***Victorian Safe Drinking Water Act 2003 (SDWA)***

The Victorian State Government passed the *Safe Drinking Water Act* in June 2003. This Act provides details of further requirements for Victorian water corporations.

The purpose of the *Safe Drinking Water Act (2003)* is to make provision for the supply of safe drinking water. In outline this Act:

- requires water suppliers and water storage managers to prepare and implement plans to manage risks in relation to drinking water and some types of non-potable water;
- provides for the auditing of those plans by approved auditors;
- requires water suppliers to ensure that the drinking water they supply meets quality standards specified by the regulations;
- requires water suppliers to disclose to the public information concerning the quality of drinking water;
- provides for the variation, after community consultation, of water quality standards that relate only to aesthetic factors;
- requires the reporting of known or suspected contamination of drinking water to the Secretary to the Department of Health and Human Services; and
- empowers the Secretary to enforce this Act.

- ***Victorian Safe Drinking Water Regulations 2015 (SDWR 2015)***

The Victorian State Government passed the *Safe Drinking Water Regulations* in July 2005. This act provides details of further requirements for Victorian Water Corporations. The Safe Drinking Water Regulations (2015) came into operation on 18 July 2015 with the Safe Drinking Water Regulations 2005 being revoked.

The purpose of the Safe Drinking Water Regulations (2015) is to make provision for the supply of safe drinking water. In outline, this Act:

- sets out the further matters to be addressed in risk management plans and the risks to be specified in risk management plans;
- describes the documents that are to be available for inspection in the risk management plan audit;
- prescribes the form of audit certificates to be given to the person who has commissioned a risk management plan audit at the completion of the audit;
- sets out the risk management plan auditor approval criteria;
- sets out the drinking water standards;
- sets out the requirements relating to the frequency of collection of samples of water quality analysis;
- empowers the Secretary to:
 - (i) divide areas supplied by water suppliers into water sampling localities;
 - (ii) specify locations within a water sampling locality at which samples of water are to be collected;
 - (iii) vary the frequency of collection for samples of water in certain circumstances;
- requires all samples of water collected to be analysed by an accredited laboratory and a summary of results of the analysis to be given to the Secretary;
- specifies the issues relating to the quality of drinking water, presented in an annual report every financial year, to be given to the Secretary by a water supplier and water storage manager; and
- set out details to be included in an annual report to the Secretary.

- ***Australian Drinking Water Guidelines 2011 (ADWG)***

The purpose of the *Australian Drinking Water Guidelines 2011* is to provide the authoritative reference for use within Australia's administrative and legislative framework to ensure the accountability of drinking water suppliers. The ADWG are not mandatory legally enforceable standards.

The guidelines set the framework for the management of drinking water quality known as the 12 elements.

Gippsland Water has adopted the 12 elements of the ADWG 2011 that comprise:

1. Commitment to Drinking Water Quality Management.
 - (i) Drinking Water Quality Policy
 - (ii) Regulatory and formal requirements
 - (iii) Engaging stakeholder

2. Assessment of the Drinking Water Supply System.
 - (i) Water supply system analysis
 - (ii) Assessment of water quality data
 - (iii) Hazard identification and risk assessment
3. Preventive Measures for Drinking Water Quality Management.
 - (i) Preventative measures and multiple barriers
 - (ii) Critical control points
4. Operational Procedures and Process Control.
 - (i) Operational procedures
 - (ii) Operational monitoring
 - (iii) Corrective action
 - (iv) Equipment capability and maintenance
 - (v) Materials and chemicals
5. Verification of Drinking Water Quality.
 - (i) Drinking water quality monitoring
 - (ii) Consumer satisfaction
 - (iii) Short term evaluation of results
 - (iv) Corrective action
6. Management of Incidents and Emergencies.
 - (i) Communications
 - (ii) Incident and emergency response protocols
7. Employee Awareness and Training.
 - (i) Employee awareness and involvement
 - (ii) Employee training
8. Community Involvement and Awareness.
 - (i) Community consultation
 - (ii) Communication
9. Research and Development.
 - (i) Investigative studies and research monitoring
 - (ii) Validation of processes
 - (iii) Design of equipment
10. Documentation and Reporting.
 - (i) Management of documentation and records
 - (ii) Reporting
11. Evaluation and Audit.
 - (i) Long term evaluation of results
 - (ii) Audit of drinking water quality management
12. Review and Continual Improvement
 - (i) Review by senior executive
 - (ii) Drinking water quality management improvement plan

- **Health (Fluoridation) Act 1973**

The *Health (Fluoridation) Act 1973* ('the Act') regulates the safe and effective addition of fluoride into drinking water supplies in Victoria.

Under the Act, the Secretary to the Department of Health and Human Services has the power to direct water supply authorities to commence water fluoridation.

- **Code of Practice for Fluoridation of Drinking Water Supplies; Second Edition (2018) – Health (Fluoridation) Act 1973.**

This code provides details of further requirements for Victorian water corporations.

The objective of the code is to provide for the safe and effective addition of fluoride into the drinking water supply.

This will be achieved by specifying:

- (a) the optimum fluoride levels for drinking water supplies and the design control limits for fluoridation plants;
- (b) the minimum requirements for the safe and effective addition of fluoride chemicals to drinking water supplies, covering the design and operation of a fluoridation plant; and
- (c) monitoring and reporting requirements for the proposed fluoridation scheme.

The code also includes works undertaken on fluoridation plants and integrates the practices with the SDWA through:

- (a) the inclusion of water fluoridation into the corporations' risk management plan under the SDWA; and
- (b) integration and compliance with the auditing, notification and reporting requirements of the SDWA.

The code also describes the gap analysis and subsequent works program associated with water fluoridation plant through:

- a) the regulatory frame work including the procedure to fluoridate;
- b) safety in design;
- c) requirements for the design and control of fluoridation facilities; and
- d) requirements for plant operation including monitoring, training or personnel, occupational health and safety, security and environmental protection.

- **Health Based Targets (HBT)**


The National Health and Medical Research Council (NHMRC) released a discussion paper in 2009 on introducing a health-based target (HBT) for microbial water quality in the *Australian Drinking Water Guidelines* (ADWG). In December 2011, Water Services Association of Australia's (WSAA) Water Quality Network considered the HBT proposition at their annual meeting. Outcomes from that meeting formed the basis of a subsequent WSAA submission to the National Health and Medical Research Council (NHMRC).

The WSAA *Drinking Water Source Assessment and Treatment Requirements Manual for the Application of Health-Based Treatment Targets Release No. 2 September 2015* was adopted by Gippsland Water for assessing the microbiological risk associated with its catchments and treatment processes in place (log removal requirements) to manage these risks.

The HBT comprises four parts:

- (a) **Source water assessment** (microbial risk). Pathogen risk assessment is conducted in accordance with the Water Service Association of Australia’s (WSAA) *Manual for the Application of Health-Based Treatment Targets Release No 2* and is consistent with the ADWG 2011 Framework. Figure 2-1 below sets out WSAA’s approach to quantitative risk assessment that has been adopted by the Corporation

Figure 1: WSAA Water Safety Assessment Process



- (b) **Water treatment plant process assessment** The water treatment assessment involves assigning estimates of pathogen reduction to the treatment processes deployed at a source.
- (c) **Water safety assessment** Comparing the log reduction required from the source assessment with the log reduction values claimable from the water treatment assessment.
- (d) **Water Safety Improvement Plan** The water safety improvement plan involves planning improvements to improve water safety. Where the HBT is not achieved, the water supplier should undertake improvements.

3 DRINKING WATER QUALITY POLICY



WATER QUALITY

GIPPSLAND WATER'S DRINKING WATER QUALITY POLICY

We are committed to managing our “catchment to tap water supply systems” to provide safe drinking for our customers at all times.

We will demonstrate compliance with the current Safe Drinking Water Regulations, Safe Drinking Water Act and subordinate regulations.

We will openly and transparently report to customers, employees, the Board and external parties on our drinking water quality activities and performance.

www.gippswater.com.au | facebook.com/gippslandwater | twitter.com/gippswater

This page intentionally left blank

Table 1 (cont.): Gippsland Water locality water source and water treatment process

Locality	Estimated Population Served ¹	Source water	Storage	Water Treatment Plant	Treatment process									Sludge Thickening Dewatering	Added Substances						
					Coagulation & Flocculation	Clarification		Filtration		Disinfection			Other		Lime / Soda Ash	Alum Based Coagulants	Iron Based Coagulants	Potassium Permanganate	Polymers	Sodium Fluoride / Hydrofluosillic Acid	Calgon sodium hexametaphosphate
						Sedimentation / Clarification	Dissolved Air Flotation	Granular Media Filter	Membrane	Chlorine Gas	Chloramination	Sodium Hypochlorite									
Seaspray	230	Merrimans Creek	Seaspray raw water storage	Seaspray	X			X					X	X	Soda Ash	Alum 90			1115, 1160		
Thorpdale (water carting from Moe locality)	210	Tanjil River and Narracan Creek (September 2015 - ongoing)	N/A	Moe	X	X		X		X		Newborough, Yallourn North, Trafalgar, Yarragon & Darnum		X	Soda Ash	Alum			LT20	Sodium Fluoride	X
Willow Grove	350	Tanjil River	Blue Rock Lake	Willow Grove	X			X		X				X	Soda Ash	Alum			1115, 1160		

- 1 = The listed populations are for the water sampling localities calculated using 2006 census data to calculate the number of persons per dwelling per locality and then multiplying it with Gippsland Water's 2018-19 figures for number of connections. Figures have also been rounded to the nearest 10.
- 3 = The water supplied to Darnum changed from the Warragul system to the Moe system in March 2012.
- 4 = PAC/GAC used as required to treat for taste and odour compounds.
- * = PACI-23 used as required to treat high turbidity raw water.
- X₁ = Plant capability for activated carbon dosing (not currently in use).

This page intentionally left blank

4.2 WATER QUALITY MANAGEMENT SYSTEM

The *Safe Drinking Water Act 2003* (the Act) provides a regulatory framework for drinking water quality including a risk management framework and water quality standards. The Act requires all Victorian Water Corporations to prepare, implement and review a risk management plan. To assist with this requirement, Gippsland Water has made a commitment to establish and maintain a Drinking Water Quality Management System (DWQMS) that considers the principles of the Framework for the Management of Drinking Water Quality within the *Australian Drinking Water Guidelines 2011* (ADWG). This quality management framework is specific for the water industry and incorporates a preventive risk management approach from catchment to consumer.

Gippsland Water utilises the ADWG Framework principles in its Water Quality Management System for the supply of safe drinking water. The ADWG Framework is based on 12 elements outlined in Chapter 2.

The 12 elements of the Water Quality Management System must be met, and the key processes undertaken to meet these requirements include:

4.2.1 Hazard and risk identification

To determine the key risk to a water supply to enable control measures to be implemented, Gippsland Water undertakes an extensive hazard assessment process from the catchment to the end user involving management, operational staff, system operators and key stakeholders.

The risks identified during this process are reviewed regularly to identify changes to risks, new risks, or when processes and system changes occur.

4.2.2 Control measures

Control measures are established to reduce the key risk or likelihood of the risk occurring. The intent is to manage or reduce the risk to an acceptable level. Within Gippsland Water's Water Quality Management System, this consists of;

- Critical Control Points (CCPs) that are alarmed and have the ability to stop processes before a water quality failure occurs. The CCPs are documented and apply to critical process steps in the treatment process;
- maintenance programs that include preventive maintenance of critical assets used in the treatment process and control systems such as dosing systems, monitoring instrumentation for key assets and system-based maintenance such as mains flushing, air scouring, tank and basin cleaning as well as asset maintenance and replacement programs; and
- trained and competent water treatment technicians manage the operation and maintenance of water treatment plants and water supply systems. All technicians undertake industry based training to ensure a high level of knowledge of treatment processes and associated risks. Gippsland Water technicians are trained in accordance with the Department of Health and Human Services and Victorian Water Industry Association's *Framework for Water Treatment Operator Competencies (2010)* requirements to Certificate 3 and Certificate 4 level in water industry operations.

4.2.3 Verification and monitoring

Verification and monitoring is used to confirm and authenticate the performance of water treatment processes and water supply systems to ensure compliance with SDWR 2015 standards and ADWG health related and aesthetic guideline values. Verification and monitoring at Gippsland Water includes:

- Supervisory control and data acquisition systems (SCADA) at:
 - individual water treatment plants;
 - secondary disinfection systems; and
 - water supply treated water tanks, storages and pump stations.
- System-wide telemetry and alarms 24 hours a day, 7 days a week;
 - Critical Control Point (CCP) alert and critical process alarms;
- Water treatment and water quality Technicians on-call 24 hours a day, 7 days a week for system monitoring and alarm verification and response;
- a drinking water quality monitoring program covering the catchment, water treatment plant process and water supply system testing and undertaken by an independent National Association of Testing Authorities (NATA) accredited laboratory that include:
 - Pathogenic microorganisms;
 - inorganic chemicals, including inorganic disinfection by-products;
 - organic chemicals, including pesticides, pesticide residues and organic disinfection by-products;
 - radiological parameters; and
 - algal toxins (as required when algal events occur).
- A water treatment chemical quality assurance program undertaken by an independent laboratory that includes certificates of analysis prior to receipt of chemicals for use;
- calibration programs of on-line and benchtop critical instruments used for process control and alert and critical alarm processes by independent service providers; and
- customer feedback captured through Gippsland Water's water quality complaint resolution procedure.

4.2.4 System auditing

Internal and external auditing programs have been established to assess compliance of the Water Quality Management System. This includes auditing;

- Water treatment plant records, systems and processes;
- water supply system infrastructure (water mains repairs, treated water storage tanks and basins);
- challenging testing CCP alert and critical alarms; and
- behavioural audits to verify compliance with control, verification and monitoring requirements.

4.3 WATER TREATMENT PROCESSES

The source waters for Gippsland Water's 16 water supply systems are treated prior to distribution with the objective of providing safe drinking water at all times. The treatment varies for each water supply system with the specific treatment process dependent on the quality and risks of the source water.

Table 1 identifies the regular treatment process for each of the water localities and lists the added substances and any periodic treatment activities. The treatment process used depends on the source and quality of the water to be treated. The corporation uses the following treatment processes to produce safe drinking water:

4.3.1 Coagulation/flocculation

Coagulation is a process to remove very fine suspended particles often associated with turbidity, colour or colloidal matter in water. These particles have a negative charge that causes them to repel each other and stay suspended in water. The addition of a suitable 'coagulant' of iron and/or aluminium salt with a positive charge neutralises or destabilises the negative charge enabling the fine particles to join together to form larger particles. The flocculation (floc) process involves stirring the water gently after the coagulant has been added. This allows the particles to come into contact, and eventually causes it to stick together and form floc. This process removes the fine particles, dirt and colour present in the water.

Chemicals used for coagulation/flocculation at the water treatment plants include aluminium sulphate, ferric sulphate and poly-aluminium silicate sulphate solution (PASS).

4.3.2 Clarification/sedimentation

The clarification or sedimentation of the floc particles formed during the coagulation/flocculation process is usually carried out under still conditions (e.g. in the sedimentation tank or clarifier). A sedimentation tank relies on gravity to separate the floc from the water, which is heavy and falls to the bottom of the tank – leaving the 'cleaner' water on top. A clarifier uses a mechanical process to separate the floc, and the water is collected in troughs at the surface. Once the floc has been removed the clean water is sent to filters.

4.3.3 Membrane filtration

Membrane filtration is used to remove suspended solids and some colloidal matter from the source water. The water is pumped through the filter membrane trapping suspended solids in the process. The concentrate (material that does not pass through the membrane) is periodically removed to waste to prevent the blocking of the membrane filters.

4.3.4 Filtration

The clarified water is passed through a filter consisting of several types of graded filter media (sand, gravel and coal) to remove any remaining particles, floc or dissolved chemicals that may have passed through the clarification/sedimentation process.

Another method used utilises Dissolved Air Flotation and Filtration (DAFF) which relies on the injection of microscopic air particles into the water stream, causing the flocculated particles to

float to the surface. These particles are then drawn off the surface and off the filtration tank and removed to waste. The clear water then is filtered, as above, through graded filter media.

Over time, the filters gradually become clogged with trapped particles. A filter backwash is carried out to clean the filters, returning it to optimum condition. Air and water is forced up through the filter nozzles to agitate the filter bed and remove any trapped particles. The final turbidity of water leaving the filters, during normal plant operation, is less than 0.1 NTU (Nephelometric Turbidity Units - unit of measure for turbidity).

The backwash water produced during the filter cleaning process is discharged to the sludge thickening system to separate solids from process water. To maximise water use, the separated process water is then returned to the treatment plant and mixed with new raw water to recommence the treatment process.

4.3.5 Sequestration

Sequestration involves the addition of sequestering agents followed by chlorination which keeps dissolved iron and manganese from oxidising and precipitating.

4.3.6 Disinfection

Drinking water is disinfected to prevent the spread of waterborne pathogens that cause diseases such as dysentery, cholera, typhoid and gastroenteritis.

A low residual level of disinfection also ensures that the water remains disinfected once it leaves the water treatment plant until it arrives at the customer's tap.

In Gippsland Water's service area, chlorination is the most commonly used disinfectant because of its reliability and cost effectiveness. Chlorine is the most widely used disinfectant for drinking water supplies in the world. The other disinfection treatment process used in our region is chloramination.

Chlorination

Chlorine is widely used throughout the world to disinfect drinking water and control disease causing organisms. The type of chlorine used at our plants is either chlorine gas or sodium hypochlorite.

Chloramination

Chloramination is also used throughout the world as a means of disinfecting drinking water to control disease causing organisms. Small amounts of chlorine and ammonia are added to the water to form chloramines, providing a relatively long lasting process to safely disinfect water.

Secondary disinfection

Disinfectant residuals decrease as water passes throughout the distribution system and within storage tanks. Secondary water disinfection plants are used to maintain adequate disinfection levels within the distribution system.

Gippsland Water operates a number of chlorination secondary disinfection sites that are in place to ensure disinfection residuals are maintained throughout the distribution system by topping up chlorine levels to maintain a balance between adequate disinfection residuals and aesthetic water quality.

4.3.7 Added substances

Lime/Soda ash

To assist with the treatment process and to ensure the pH level in the raw water (before treatment chemicals are added) and filtered water (after treatment) is within the required ranges, lime or soda ash is added. Lime or soda ash is added to the raw water to adjust the pH to ensure the optimum level for chemical reactions to occur in the coagulation/flocculation process.

Lime or soda ash is also added to the water before it leaves the water treatment plant to maintain the pH in the desired range to optimise the effectiveness of disinfection chlorinated systems and to minimise the risk of corrosion and improve water taste.

Potassium permanganate

Potassium permanganate can be added to the water supply as required to reduce iron and manganese levels. When present in higher concentrations, these metals can cause staining of laundry and plumbing fixtures and contribute to 'dirty water' events.

Powdered activated carbon

Powdered activated carbon can be added to the water supply as required to remove compounds that contribute to taste and odour issues, usually associated with higher levels of certain algae in raw water.

Fluoridation

In accordance with DHHS requirements, Gippsland Water fluoridates the drinking water supplies at 6 of its 16 water treatment plants (Moe, Morwell, Maffra, Traralgon, Sale, and Warragul). Any fluoride present in those systems that do not have fluoride dosing systems is due to naturally occurring sources. For information about the health issues associated with the water fluoridation program, contact the Department of Health and Human Services (DHHS) on 1800 651 723.

Sodium hexametaphosphate

Sodium hexametaphosphate can be added to the water supply as required as a sequestration agent to prevent the oxidation of trace levels of manganese in the water supply that can contribute to dirty water issues.

4.3.8 Distribution

After water is filtered and disinfected, it is relayed to customers through a vast network of tanks, basins, pumps and pipes. Gippsland Water uses positive pressure, gravity and backflow prevention to ensure safe drinking water. Positive pressure pushes contaminants away from the water supply system if leaks occur. The corporation requires high risk properties install a testable backflow prevention device before connecting to the water supply network.

5 SYSTEM ISSUES FOR 2018-19

During the 2018-19 monitoring period, there were no events reportable under Section 22 of the SDWA, and as such is detailed in Section 5 of this report.

Systems issues across the year included:

Water carting to the Coongulla and Glenmaggie townships commenced in April 2019 when water levels in Lake Glenmaggie fell to a point where we could no longer extract raw water for treatment. Water carting is ongoing as of 30 June 2019, and will continue until the water level rises to a level, and is of a quality, to allow pumping and treatment to recommence.




Figure 2: Lake Glenmaggie May 2019

Any other non-reportable systems issues were dealt with through the customer water quality complaints process outlined in section 6.

6 QUALITY OF DRINKING WATER 2018-19

The SDWR require a water quality monitoring program to be undertaken to verify compliance or non-compliance of specified water quality parameters as listed in the regulations. The quality of water is measured across each of the 35 localities to determine that the water meets the specified quality standard. Over the reporting period, approximately 2,500 samples were collected for quality testing and over 28,000 tests performed. The following section provides a summary of the results against the water quality parameters monitored through the year at the required sampling frequency.

A brief explanation of the required water quality parameters is provided below. A more detailed explanation can be obtained from the ADWG prepared by the National Health and Medical Research Council (NHMRC).

(<https://nhmrc.gov.au/about-us/publications/australian-drinking-water-guidelines#block-views-block-file-attachments-content-block-1>)

6.1 WATER QUALITY STANDARDS (SDWR 2015)

Escherichia coli (E. coli) – *E. coli* is the most common thermo-tolerant coliform present in faeces and is regarded as the most specific indicator of recent faecal contamination from warm blooded animals. The presence of *E. coli* in the water supply can therefore indicate the potential for other pathogenic bacteria to be present. Results from samples taken within the locality that exceed the maximum level of this parameter are reported to DHHS, as required under Section 18 of the SDWA.

Trihalomethanes (THM) – Trihalomethanes are a category of by-products produced in drinking water, principally as a result of disinfection chemicals (chlorine) reacting with naturally occurring organic matter derived from the decay of aquatic and terrestrial vegetative matter present in water supplies. Results from samples taken within the locality that exceed the maximum level of this parameter are reported to DHHS, as required under Section 18 of the SDWA.

Turbidity – Turbidity is caused by the presence of fine suspended matter such as clay, silt, colloidal particles, algae and other microscopic organisms in the water. In high levels, this matter gives the water the appearance of being dirty, muddy or milky. Turbidity is best removed by coagulation and filtration treatment processes. Results from samples taken within the locality that exceed the maximum level of this parameter are reported to DHHS, as required under Section 18 of the SDWA.

The *Safe Drinking Water Regulations (2015)* monitoring requirements are summarised in Table 2:

Table 2: Summary of the Safe Drinking Water Regulations 2015 (Schedule 2):

Parameter	SDWR (2015) Water Quality Standard
<i>Escherichia coli</i>	All samples of drinking water collected are found to contain no <i>Escherichia coli</i> per 100 millilitres, with the exception of any false positive sample.
Trihalomethanes	0.25 mg/L
Turbidity	The 95th percentile of results for samples in any 12 month period must be less than or equal to 5.0 Nephelometric Turbidity Units.

6.2 WATER QUALITY STANDARDS

Gippsland Water must ensure that all drinking water supplied to its localities complies with the quality standards specified under Part 3 of the SDWA (2003). As well as the above parameters that are required under Schedule 2 of the SDWR (2015), many other tests are conducted to ensure that the water supplied is safe to drink. These parameters are determined by assessing the risks to each system and monitoring to verify that these risks are being controlled effectively.

The quality standards applied for the additional parameters in most instances are derived from the ADWG.

6.3 EMERGENCY/INCIDENT MANAGEMENT

Gippsland Water has aligned its incident/emergency management approach to the Australasian Inter-service Incident Management Systems (AIIMS) as part of its SDWA and SDWR emergency and incident management processes.

Gippsland Water has audited and updated its All Hazards Incident Management Plan in June 2016 to comply with the requirements of Part 7a of the *Emergency Management Act (2013)*.

6.4 INCIDENT AND POTENTIAL WATER QUALITY EVENTS

Section 18 of the SDWA states:

'A water supplier must notify the Secretary in writing if it becomes aware that the drinking water it is supplying to another person does not comply, or is not likely to comply, with any relevant water quality standard and must do so within 10 days after it becomes aware of the fact.'

In 2018-19, the water quality events reported to the DHHS pursuant to section 18 of the SDWA are summarised below.

Table 3: Summary of notifications under Section 18

Water Sampling Locality Affected	Date and duration of incident	Location of incident	Nature of the incident	Drinking water supplies affected	Safe Drinking Water Regulations (Schedule 2) – Standard Not Met
There were no events reported to the DHHS pursuant to section 18.					

6.5 EMERGENCIES AND WATER QUALITY EVENTS

Section 22 of the SDWA states:

'(1) This section applies if an officer of a water supplier believes or suspects on reasonable grounds that the water supplied, or to be supplied for drinking purposes –

- (a) may be the cause of illness; or
- (b) may be the means by which an illness is being, has been or will be transmitted; or
- (c) may contain any pathogens, substance, chemical or blue-green algae toxin, whether alone or in combination, at levels that may pose a risk to human health; or
- (d) may cause widespread public complaint.

'(2) On forming that belief or suspicion, the officer must immediately report his or her belief or suspicion to the Secretary, and must make the report in the form required by the Secretary.'

During the 2018-19 reporting year, there were no reportable events that required notification to the Drinking Water Regulatory Unit of DHHS, under section 22 of the SDWA.

Table 4: Summary of incidents and actions taken under Section 22

Water Sampling Locality Affected	Date and duration of incident	Location of incident	Nature of the incident	Drinking water supplies affected	Actions taken in response to the incident	Was the community notified
There were no events reported to the DHHS pursuant to section 22.						

6.6 OTHER EVENTS NOT REPORTABLE

In August 2018 taste and odour issues were identified in the Maffra drinking water supply. The cause was the breakdown of organic material in the raw water. The water treatment powdered activated carbon system was optimised to remove the taste compounds.

7 COMPLAINTS

7.1 WATER QUALITY COMPLAINTS

Gippsland Water is committed to providing safe drinking water to our customers at all times. Gippsland Water records all complaints relating to drinking water quality. The types of water quality complaints logged by Gippsland Water are classified as follows:

- ❑ Discoloured/Dirty water;
- ❑ Taste/Odour;
- ❑ Blue water;
- ❑ Air in water;
- ❑ Alleged illness.

The complaints are compared to the number of customers (per 100 customers) to enable comparisons with other water supplies and localities. A summary of customer complaints received by Gippsland Water relating to the quality of drinking water supplied is reported below.


Each water quality complaint received is responded to as per Figure 6 whereby the customer complaint is logged by Gippsland Water's Customer Service or after hours staff, and a Gippsland Water representative responds to the complaint and initiates any corrective actions as required.

Table 5: Water quality complaints per 100 customers supplied

Type of Complaint	2018-19		2017-18	2016-17	2015-16	2014-15
	No. of Complaints	Complaints per 100 customers	Complaints per 100 customers	Complaints per 100 customers	Complaints per 100 customers	Complaints per 100 customers
Discoloured water	108	0.166	0.112	0.124	0.185	0.239
Taste / Odour	49	0.075	0.084	0.083	0.112	0.115
Blue water	1	0.002	0.000	0.002	0.003	0.006
Air in water	27	0.041	0.031	0.026	0.026	0.064
Alleged illness	6	0.009	0.020	0.014	0.012	0.014
Total	191	0.293	0.247	0.248	0.339	0.439

The total number of complaints received by Gippsland Water during the 2018-19 reporting period was similar to the 2015-18 reporting period. The results are presented below by type and locality.

Figure 3: Total customer complaints for 2004-05 to 2018-19



When calculating the number of complaints per 100 customers, there were no localities within Gippsland Water’s supply district which exceeded four complaints per 100 customers, as represented in the figure below.

Figure 4: Customer complaints per 100 customers for 2018-19




Figure 5: Customer water quality complaints by type 2018-19

The majority of customer complaints for the 2018-19 period related to discoloured/dirty water followed by taste and odour (Figure 5):




Table 6: Customer complaints summary for each sampling locality 2018-19

Water Quality Locality	Population (Customers = Number of Connections)	Total Complaints Received 2018-19	No. Complaints per 100 customers 2018-19
Boisdale	35	0	0.000
Boolarra	309	0	0.000
Briagolong	338	0	0.000
Churchill	2219	8	0.346
Coongulla/Glenmaggie	409	4	0.983
Cowwarr	116	0	0.000
Drouin	5632	21	0.382
Erica	141	0	0.000
Heyfield	954	2	0.211
Jumbuk	152	1	0.658
Maffra	2436	13	0.537
Mirboo North	790	5	0.617
Moe	5437	8	0.144
Morwell	8011	11	0.137
Neerim South	578	8	1.452
Newborough	2642	7	0.218
Noojee	134	5	3.497
Rawson	195	4	2.020
Rokeby / Buln Buln	194	0	0.000
Rosedale	806	1	0.125
Sale / Wurruk	7323	10	0.128
Seaspray	345	4	1.166
Stratford	933	3	0.331
Thorpdale	92	1	1.099
Toongabbie	368	1	0.274
Trafalgar	1836	11	0.632
Traralgon	13301	25	0.190
Traralgon South / Hazelwood Nth	696	5	0.730
Tyers / Glengarry	797	1	0.126
Warragul	7824	23	0.299
Warragul South	195	0	0.000
Willow Grove	161	1	0.667
Yallourn North	702	3	0.426
Yarragon	1173	4	0.561
Yinnar	505	1	0.201

7.2 A SUMMARY OF THE CUSTOMER COMPLAINT PROCESS


Customer complaints are managed according to the following summary procedure:

- Customer complaints received by Gippsland Water’s Customer Contact Centre are recorded in a database. Details include information of who, where, time and nature of complaint.
- The Water Quality Group investigates by visiting the site and contacting the customer if necessary to determine details of the water quality problem.

- For complaints associated with taste and odour, dirty water, and air in pipes, field measurements are performed, the reticulation system is typically flushed then field measurements are taken again to verify the problem has been corrected.
- Follow up contact may be made with the customer to determine if they are satisfied with the quality of service, or alternatively a standard Gippsland Water contact card is left with the customer. This also encourages customers to keep Gippsland Water informed of any reoccurrence of water quality problems.
- Details of actions undertaken are entered into a database to provide a record/history of the site, to document issues for maintenance programs, and to inform capital upgrade requirements where a history of system failures occurs.

This procedure is presented in more detail in the figure on the following page.

Figure 6: Water quality complaints resolution procedure



This page intentionally left blank

8 RISK MANAGEMENT PLAN AUDIT

Gippsland Water's Water Quality Risk Management Plan has been operational since 2005 and adopts the 12 elements outlined in the ADWG and preventative risk management strategies outlined in the SDWA.


Gippsland Water's Water Quality Risk Management Plan was last audited in April 2018 by DHHS approved (Exemplar Global) auditors for compliance with section 7(1) of the SDWA 2003.

Gippsland Water was found to be compliant with the requirements of the Act and Regulations. Two opportunities for improvement (OFI) were identified during the audit which were completed during the 2018-19 reporting period. A copy of the risk management plan audit certificate is attached in Appendix 2.

The audit also examined if opportunities identified in the previous audit (March 2014) had been satisfactorily addressed.

No audit was completed in the 2018-19 period.

Table 7: Risk Management Plan Completed Opportunity for Improvements

Opportunity for Improvement (OFI)	GW Action Identified
<p>OFI 1: Gippsland Water develop and implement a timely program to expedite the implementation of the backflow prevention program</p>	<p>GW Action: A Gippsland Water 2016-17 corporate project had already been identified for backflow prevention. Review of backflow prevention requirements including re-assessment of residential and non-residential customers register and an action plan to risk assess and rank against AS/NZ Std, review business policy and procedures with respect to processing of applications (fire service, trade waste customer), notification of customers identified, registration at GW in billing system, annual testing requirements letter , data/document management , annual audit plan has been developed and is currently being actioned</p> <p>Responsible Workgroup – Property Services</p> <ul style="list-style-type: none"> ▪ Permanent Fulltime Backflow Prevention Role appointed ▪ Steering committee Terms of Reference established ▪ High risk installations have been identified and implementation of the action plan underway <p><i>Action is closed</i></p>
<p>OFI 2: Gippsland Water expedite the implementation of the clean-up and vermin-proofing of the Warragul store area, rectify the potential contamination from the nearby WWTP, bag parts and create a more fit-for-purpose storage facility</p>	<p>GW Action: Gippsland Water have already undertaken a review of the site and actions had been identified prior to the audit. An action plan is in place to rectify as part of the 2017-18 capital improvement program.</p> <p>Responsible Workgroup – Field Services Field Services have implemented vermin proofing and security of the shed to remove potential for contamination – <i>Action is closed</i></p> 

9 WATER QUALITY RESULTS FOR 2018-19

9.1 ESCHERICHIA COLI (E. COLI)

9.1.1 E. coli results

Compliance under the SDWR (2015) requires all samples of drinking water collected within a locality to contain no *E. coli* organism/100mL of drinking water. All Gippsland Water localities achieved compliance with this standard for the 2018-19 reporting period.

Table 8 below details all *E.coli* notifications for the reporting period 1 July 2018 to 30 June 2019 under the *Safe Drinking Water Regulations (2015)*.

Table 8: *E. coli* detections for localities 2018-19

Locality	No. of investigations conducted (s.22)	No. of confirmed false positives	No. of investigations where standard not met (s.18)
No Detection	0	0	0

Table 9: *E. coli* results for all localities for 2018-19

Locality	Frequency of Sampling	Number of samples*	Maximum Detected (orgs/100mL)	No. of detections and investigations conducted (s.22)	No. of samples where standard was not met (s.18)
Boisdale	Weekly	104	0	0	0
Boolarra	Weekly	104	0	0	0
Briagolong	Weekly	106	0	0	0
Churchill	Weekly	171	0	0	0
Coongulla-Glenmaggie	Weekly	104	0	0	0
Cowwarr	Weekly	52	0	0	0
Drouin	Weekly	156	0	0	0
Erica	Weekly	52	0	0	0
Heyfield	Weekly	105	0	0	0
Jumbuk	Weekly	104	0	0	0
Maffra	Weekly	118	0	0	0
Mirboo North	Weekly	104	0	0	0
Moe	Weekly	156	0	0	0
Morwell	Weekly	228	0	0	0
Neerim South	Weekly	104	0	0	0
Newborough	Weekly	104	0	0	0
Noojee	Weekly	156	0	0	0
Rawson	Weekly	104	0	0	0
Rokeby-Buln Buln	Weekly	52	0	0	0
Rosedale	Weekly	104	0	0	0
Sale-Wurruk	Weekly	193	0	0	0
Seaspray	Weekly	104	0	0	0

Table 9: *E. coli* results for all localities for 2018-19 (cont.)

Locality	Frequency of Sampling	Number of samples*	Maximum Detected (orgs/100mL)	No. of detections and investigations conducted (s.22)	No. of samples where standard was not met (s.18)
Stratford	Weekly	52	0	0	0
Thorpdale	Weekly	104	0	0	0
Toongabbie	Weekly	104	0	0	0
Trafalgar	Weekly	116	0	0	0
Traralgon	Weekly	157	0	0	0
Traralgon South-Hazelwood North	Weekly	52	0	0	0
Tyers-Glengarry	Weekly	104	0	0	0
Warragul	Weekly	197	0	0	0
Warragul South	Weekly	104	0	0	0
Willow Grove	Weekly	104	0	0	0
Yallourn North	Weekly	104	0	0	0
Yarragon	Weekly	104	0	0	0
Yinnar	Weekly	52	0	0	0

*= The number of samples collected is based on the population of the locality and is calculated based on the guidance provided in ADWG (2014) - Table 9.4 Recommended minimum frequency of *E. coli* monitoring.

Table 10: Comparison of *E. coli* results for previous years (2016 - 2019)

Locality	2018 - 2019		2017 - 2018		2016- 2017	
	Maximum Detected (orgs/100mL)	No. of samples where standard was not met (s.18)	Maximum Detected (orgs/100mL)	No. of samples where standard was not met (s.18)	Maximum Detected (orgs/100mL)	No. of samples where standard was not met (s.18)
Boisdale	0	0	0	0	0	0
Boolarra	0	0	1	0	0	0
Briagolong	0	0	0	0	0	0
Churchill	0	0	0	0	0	0
Coongulla/Glenmaggie	0	0	0	0	0	0
Cowwarr	0	0	0	0	0	0
Drouin	0	0	0	0	0	0
Erica	0	0	0	0	0	0
Heyfield	0	0	0	0	0	0
Jumbuk	0	0	0	0	0	0
Maffra	0	0	0	0	0	0
Mirboo North	0	0	0	0	0	0
Moe	0	0	0	0	0	0
Morwell	0	0	0	0	0	0
Neerim South	0	0	0	0	1	0
Newborough	0	0	0	0	0	0

Table 10: Comparison of E. coli results for previous years (2016 – 2019) (cont.)

Locality	2018 - 2019		2017 - 2018		2016- 2017	
	Maximum Detected (orgs/100mL)	No. of samples where standard was not met (s.18)	Maximum Detected (orgs/100mL)	No. of samples where standard was not met (s.18)	Maximum Detected (orgs/100mL)	No. of samples where standard was not met (s.18)
Noojee	0	0	0	0	0	0
Rawson	0	0	0	0	0	0
Rokeyby/Buln Buln	0	0	0	0	0	0
Rosedale	0	0	0	0	0	0
Sale/Wurruk	0	0	0	0	0	0
Seaspray	0	0	0	0	0	0
Stratford	0	0	0	0	0	0
Thorpdale	0	0	0	0	0	0
Toongabbie	0	0	0	0	0	0
Trafalgar	0	0	0	0	0	0
Traralgon	0	0	0	0	0	0
Traralgon South/ Hazelwood North	0	0	0	0	0	0
Tyers/Glengarry	0	0	0	0	0	0
Warragul	0	0	0	0	0	0
Warragul South	0	0	0	0	0	0
Willow Grove	0	0	0	0	0	0
Yallourn North	0	0	0	0	0	0
Yarragon	0	0	0	0	0	0
Yinnar	0	0	0	0	0	0

Results obtained for the 2018 – 2019 reporting period for each of the localities was similar to that of previous years.

9.1.2 Actions taken in relation to non-compliance

All localities complied with this water quality parameter.

9.2 CHLORINE BASED DISINFECTION BY-PRODUCT CHEMICALS

9.2.1 Trihalomethanes (THM) results

For compliance with the SDWR (2015), a sample result must not exceed 0.25 mg/L trihalomethanes. All Gippsland Water sites achieved 100% compliance with this standard for the 2018-19 reporting period.

Table 11: Trihalomethanes results for all localities for 2018-19

Locality	Frequency of sampling	No. of samples	No. of non-complying samples	Max (mg/L)	Min (mg/L)	Complying (Yes/No)
Boisdale	Monthly	12	0	0.036	0.021	Yes
Boolarra	Monthly	12	0	0.072	0.044	Yes
Briagolong	Monthly	12	0	0.006	0.001	Yes
Churchill	Monthly	12	0	0.068	0.019	Yes
Coongulla-Glenmaggie	Monthly	12	0	0.020	0.009	Yes
Cowwarr	Monthly	12	0	0.073	0.050	Yes
Drouin	Monthly	12	0	0.096	0.049	Yes
Erica	Monthly	12	0	0.040	0.015	Yes
Heyfield	Monthly	12	0	0.027	0.014	Yes
Jumbuk	Monthly	12	0	0.088	0.040	Yes
Maffra	Monthly	12	0	0.027	0.010	Yes
Mirboo North	Monthly	12	0	0.052	0.024	Yes
Moe	Monthly	12	0	0.048	0.019	Yes
Morwell	Monthly	12	0	0.041	0.017	Yes
Neerim South	Monthly	12	0	0.070	0.028	Yes
Newborough	Monthly	12	0	0.051	0.029	Yes
Noojee	Monthly	12	0	0.047	0.026	Yes
Rawson	Monthly	12	0	0.027	0.015	Yes
Rokeby-Buln Buln	Monthly	12	0	0.094	0.053	Yes
Rosedale	Monthly	12	0	0.085	0.040	Yes
Sale-Wurruk	Monthly	12	0	0.029	0.015	Yes
Seaspray	Monthly	12	0	0.190	0.100	Yes
Stratford	Monthly	12	0	0.032	0.016	Yes
Thorpdale	Monthly	12	0	0.074	0.044	Yes
Toongabbie	Monthly	12	0	0.065	0.047	Yes
Trafalgar	Monthly	12	0	0.041	0.026	Yes
Traralgon	Monthly	12	0	0.064	0.011	Yes
Traralgon South-Hazelwood North	Monthly	12	0	0.045	0.025	Yes
Tyers-Glengarry	Monthly	12	0	0.064	0.036	Yes
Warragul	Monthly	12	0	0.081	0.047	Yes
Warragul South	Monthly	12	0	0.100	0.059	Yes
Willow Grove	Monthly	12	0	0.001	<0.001	Yes
Yallourn North	Monthly	12	0	0.050	0.036	Yes
Yarragon	Monthly	12	0	0.094	0.035	Yes
Yinnar	Monthly	12	0	0.056	0.029	Yes

Table 12: Comparison of Trihalomethane (THM) results for previous years (2016 - 2019)

Locality	2018 - 2019		2017 - 2018		2016- 2017	
	Maximum THM in a sample (mg/L)	Complying (Yes/No)	Maximum THM in a sample (mg/L)	Complying (Yes/No)	Maximum THM in a sample (mg/L)	Complying (Yes/No)
Boisdale	0.036	Yes	0.057	Yes	0.062	Yes
Boolarra	0.072	Yes	0.076	Yes	0.086	Yes
Briagolong	0.006	Yes	0.010	Yes	0.010	Yes
Churchill	0.068	Yes	0.080	Yes	0.069	Yes
Coongulla/Glenmaggie	0.020	Yes	0.018	Yes	0.009	Yes
Cowwarr	0.073	Yes	0.075	Yes	0.080	Yes
Drouin	0.096	Yes	0.080	Yes	0.077	Yes
Erica	0.040	Yes	0.036	Yes	0.042	Yes
Heyfield	0.027	Yes	0.037	Yes	0.031	Yes
Jumbuk	0.088	Yes	0.097	Yes	0.101	Yes
Maffra	0.027	Yes	0.047	Yes	0.049	Yes
Mirboo North	0.052	Yes	0.056	Yes	0.039	Yes
Moe	0.048	Yes	0.060	Yes	0.044	Yes
Morwell	0.041	Yes	0.040	Yes	0.042	Yes
Neerim South	0.070	Yes	0.060	Yes	0.049	Yes
Newborough	0.051	Yes	0.069	Yes	0.052	Yes
Noojee	0.047	Yes	0.033	Yes	0.031	Yes
Rawson	0.027	Yes	0.040	Yes	0.035	Yes
Rokeby/Buln Buln	0.094	Yes	0.087	Yes	0.086	Yes
Rosedale	0.085	Yes	0.120	Yes	0.112	Yes
Sale/Wurruk	0.029	Yes	0.032	Yes	0.027	Yes
Seaspray	0.190	Yes	0.170	Yes	0.169	Yes
Stratford	0.032	Yes	0.050	Yes	0.051	Yes
Thorpdale	0.074	Yes	0.100	Yes	0.079	Yes
Toongabbie	0.065	Yes	0.065	Yes	0.064	Yes
Trafalgar	0.041	Yes	0.064	Yes	0.044	Yes
Traralgon	0.064	Yes	0.075	Yes	0.050	Yes
Traralgon South/ Hazelwood North	0.045	Yes	0.049	Yes	0.062	Yes
Tyers/Glengarry	0.064	Yes	0.059	Yes	0.064	Yes
Warragul	0.081	Yes	0.081	Yes	0.088	Yes
Warragul South	0.100	Yes	0.095	Yes	0.099	Yes
Willow Grove	0.001	Yes	0.001	Yes	0.003	Yes
Yallourn North	0.050	Yes	0.079	Yes	0.066	Yes
Yarragon	0.094	Yes	0.075	Yes	0.052	Yes
Yinnar	0.056	Yes	0.064	Yes	0.074	Yes

Results obtained for each of the localities was similar to the previous two reporting periods.

9.2.2 Actions taken in relation to non-compliance

All localities complied with this water quality parameter.

9.3 TURBIDITY

9.3.1 Turbidity results

For compliance with the SDWR (2015), the 95th percentile of results for samples of drinking water collected in any 12-month period, must be less than or equal to 5.0 NTU (Nephelometric Turbidity Unit). All Gippsland Water sites achieved 100% compliance with this standard for the 2018-19 reporting period.

Table 13: Turbidity results for all localities in 2018-19

Locality	Frequency of Sampling	Number of Samples	Maximum turbidity in a sample (NTU)	Maximum 95 th Percentile of turbidity results in any 12 months (NTU)	No. of 95 th Percentile of results in any 12 months above standard (s.18)	Complying (Yes/No)
Boisdale	Weekly	52	0.3	0.1	0	Yes
Boolarra	Weekly	52	0.4	0.3	0	Yes
Briagolong	Weekly	52	0.1	0.1	0	Yes
Churchill	Weekly	52	0.5	0.2	0	Yes
Coongulla/Glenmaggie	Weekly	52	0.2	0.2	0	Yes
Cowwarr	Weekly	52	0.2	0.1	0	Yes
Drouin	Weekly	52	0.2	0.1	0	Yes
Erica	Weekly	52	1.3	0.7	0	Yes
Heyfield	Weekly	52	0.3	0.2	0	Yes
Jumbuk	Weekly	52	0.3	0.2	0	Yes
Maffra	Weekly	52	0.1	0.1	0	Yes
Mirboo North	Weekly	52	0.3	0.1	0	Yes
Moe	Weekly	52	4.4	0.6	0	Yes
Morwell	Weekly	52	0.1	0.1	0	Yes
Neerim South	Weekly	52	0.3	0.2	0	Yes
Newborough	Weekly	52	2.8	0.4	0	Yes
Noojee	Weekly	52	0.4	0.4	0	Yes
Rawson	Weekly	52	2.2	0.9	0	Yes
Rokeby/Buln Buln	Weekly	52	0.2	0.1	0	Yes
Rosedale	Weekly	52	0.3	0.2	0	Yes
Sale/Wurruk	Weekly	52	0.1	0.1	0	Yes
Seaspray	Weekly	52	1.9	0.7	0	Yes
Stratford	Weekly	52	0.4	0.3	0	Yes
Thorpdale	Weekly	52	0.7	0.3	0	Yes
Toongabbie	Weekly	52	0.1	0.1	0	Yes
Trafalgar	Weekly	52	0.7	0.3	0	Yes
Traralgon	Weekly	52	0.1	0.1	0	Yes
Traralgon South/ Hazelwood North	Weekly	52	0.5	0.2	0	Yes
Tyers/Glengarry	Weekly	52	2.6	0.2	0	Yes
Warragul	Weekly	105	0.4	0.2	0	Yes
Warragul South	Weekly	52	0.1	0.1	0	Yes
Willow Grove	Weekly	52	0.1	0.1	0	Yes
Yallourn North	Weekly	52	0.6	0.4	0	Yes
Yarragon	Weekly	52	0.7	0.2	0	Yes
Yinnar	Weekly	52	0.4	0.3	0	Yes

*For calculation purposes, all results reported as <0.1 NTU were rounded to 0.1 NTU for calculating the maximum 95th percentile.

Table 14: Comparison of Turbidity results for previous years (2016 - 2019)

Locality	2018 - 2019		2017 - 2018		2016- 2017	
	Maximum turbidity in a sample (NTU)	Maximum 95 th Percentile of turbidity results in any 12 months (NTU)	Maximum turbidity in a sample (NTU)	Maximum 95 th Percentile of turbidity results in any 12 months (NTU)	Maximum turbidity in a sample (NTU)	Maximum 95 th Percentile of turbidity results in any 12 months (NTU)
Boisdale	0.3	0.1	0.2	0.1	0.2	0.1
Boolarra	0.4	0.3	0.4	0.3	0.4	0.3
Briagolong	0.1	0.1	0.1	0.1	0.3	0.1
Churchill	0.5	0.2	1.1	0.1	0.2	0.1
Coongulla/Glenmaggie	0.2	0.2	0.4	0.2	0.5	0.5
Cowwarr	0.2	0.1	0.2	0.1	0.5	0.2
Drouin	0.2	0.1	0.6	0.2	0.3	0.2
Erica	1.3	0.7	3.1	1.4	1.8	0.6
Heyfield	0.3	0.2	0.3	0.3	0.4	0.3
Jumbuk	0.3	0.2	0.3	0.2	0.2	0.2
Maffra	0.1	0.1	0.3	0.2	0.1	0.1
Mirboo North	0.3	0.1	0.4	0.2	0.6	0.1
Moe	4.4	0.6	0.4	0.1	0.4	0.1
Morwell	0.1	0.1	0.3	0.2	0.4	0.2
Neerim South	0.3	0.2	0.2	0.2	0.2	0.2
Newborough	2.8	0.4	1.4	0.8	0.2	0.1
Noojee	0.4	0.4	0.3	0.3	0.4	0.3
Rawson	2.2	0.9	0.2	0.2	0.4	0.2
Rokeby/Buln Buln	0.2	0.1	0.3	0.1	0.4	0.2
Rosedale	0.3	0.2	4.7	1.0	0.4	0.4
Sale/Wurruk	0.1	0.1	0.2	0.2	0.4	0.1
Seaspray	1.9	0.7	0.9	0.7	0.8	0.7
Stratford	0.4	0.3	1.4	0.6	0.3	0.2
Thorpdale	0.7	0.3	0.6	0.5	0.4	0.2
Toongabbie	0.1	0.1	0.3	0.1	0.3	0.3
Trafalgar	0.7	0.3	0.1	0.1	0.2	0.1
Traralgon	0.1	0.1	0.6	0.1	0.5	0.2
Traralgon South/ Hazelwood North	0.5	0.2	0.8	0.1	0.2	0.1
Tyers/Glengarry	2.6	0.2	0.5	0.2	0.2	0.1
Warragul	0.4	0.2	0.2	0.2	0.4	0.2
Warragul South	0.1	0.1	0.1	0.1	0.3	0.2
Willow Grove	0.1	0.1	0.3	0.2	0.2	0.2
Yallourn North	0.6	0.4	0.2	0.1	0.1	0.1
Yarragon	0.7	0.2	0.1	0.1	0.1	0.1
Yinnar	0.4	0.3	0.4	0.3	0.6	0.2

*For calculation purposes, all results reported as <0.1 NTU were rounded to 0.1 NTU for calculating the maximum 95th percentile.

Results obtained for each of the localities was similar to the previous two reporting periods.

9.3.2 Actions taken in relation to non-compliance

All localities complied with this water quality parameter.

9.4 FLUORIDE

Fluoride testing has been performed in the water supply systems where fluoride is added to the water (Maffra, Warragul, Sale, Traralgon, Morwell and Moe).

Gippsland Water has sampled localities on a weekly basis even though some of the localities listed in Table 11 require only monthly samples according to section 5.1.4 of the *Code of Practice for Fluoridation of Drinking Water Supplies* (i.e. if a fluoride plant supplies five or more water sampling localities then the corporation must take a sample each month from a water sampling point in each water sampling locality supplied from those plants such that a sample is collected from the distribution system at least once per week).

9.4.1 Fluoride results

Based on health considerations, no single sample concentration of fluoride in drinking water should exceed 1.5 mg/L, and the average level of fluoride should not exceed 1.0 mg/L. All Gippsland Water sites achieved 100% compliance with this standard for the 2018-19 reporting period.

The obligation target is defined as the overall annual average concentration of fluoride being greater than 0.6 mg/L, the minimum concentration required to provide health benefits to communities. All sites achieved this target for the reporting period.

Table 15: Fluoride results for all fluoridated localities in 2018-19

Treatment Plant	Locality	Frequency of Sampling	Number of Samples	Operating Target	Max (mg/L)	Min (mg/L)	Overall Average ¹ (mg/L)	Operating Average ² (mg/L)	Comply ³ (Yes/No)	Meeting Obligations ⁴ (Yes/No)
Maffra	Boisdale	Weekly	52	0.9	0.90	0.71	0.81	0.81	Yes	Yes
	Maffra	Weekly	104	0.9	0.92	0.58	0.82	0.82	Yes	Yes
	Stratford	Weekly	52	0.9	0.90	0.68	0.82	0.82	Yes	Yes
Morwell	Churchill	Weekly	52	0.9	0.92	0.80	0.86	0.86	Yes	Yes
	Boolarra	Weekly	52	0.9	0.90	0.80	0.85	0.85	Yes	Yes
	Jumbuk	Weekly	52	0.9	0.90	0.81	0.86	0.86	Yes	Yes
	Morwell	Weekly	104	0.9	1.00	0.08	0.83	0.85	Yes	Yes
	Traralgon South/ Hazelwood North	Weekly	52	0.9	0.95	0.64	0.86	0.86	Yes	Yes
	Yinnar	Weekly	52	0.9	0.90	0.80	0.85	0.85	Yes	Yes
Moe	Moe	Weekly	104	0.9	0.92	0.35	0.80	0.81	Yes	Yes
	Newborough	Weekly	52	0.9	0.88	0.58	0.79	0.79	Yes	Yes
	Trafalgar	Weekly	52	0.9	0.90	0.50	0.80	0.81	Yes	Yes
	Yallourn North	Weekly	52	0.9	0.89	0.55	0.79	0.80	Yes	Yes
	Thorpdale ⁵	Weekly	52	0.9	0.88	0.54	0.79	0.80	Yes	Yes
	Yarragon	Weekly	52	0.9	0.96	0.54	0.80	0.82	Yes	Yes
Sale	Sale/Wurruk	Weekly	106	0.9	0.90	0.65	0.84	0.84	Yes	Yes
Traralgon	Traralgon	Weekly	104	0.9	0.90	0.20	0.79	0.80	Yes	Yes
Warragul	Drouin	Weekly	52	0.9	1.00	0.80	0.90	0.90	Yes	Yes
	Rokeby/Buln Buln	Weekly	52	0.9	1.00	0.79	0.90	0.90	Yes	Yes
	Warragul	Weekly	104	0.9	1.00	0.79	0.90	0.90	Yes	Yes
	Warragul South	Weekly	52	0.9	0.97	0.83	0.90	0.90	Yes	Yes

1 = The average value calculated based on all monitoring conducted over the 2018-19 reporting period, including when dosing did not occur.

2 = The operating average is calculated excluding the times where dosing did not occur (concentration decreased below 0.2mg/L).

3 = Complying is defined as any sample not exceeding 1.5 mg/L, or the 12-month rolling average not exceeding 1.0 mg/L.

4 = Meeting obligation is defined as the annual average concentration of fluoride was greater than 0.6 mg/L excluding when dosing did not occur.

5 = Water carting to Thorpdale from the Moe system (Trafalgar) commenced in September 2015.

Table 16: Comparison of Fluoride results for previous years (2016- 2019)

Treatment Plant	Locality	2018 - 2019			2017 - 2018			2016 - 2017		
		Max (mg/L)	Min (mg/L)	Overall Average ¹ (mg/L)	Max (mg/L)	Min (mg/L)	Overall Average ¹ (mg/L)	Max (mg/L)	Min (mg/L)	Overall Average ¹ (mg/L)
Maffra	Boisdale	0.90	0.71	0.81	0.92	0.66	0.80	0.91	<0.05	0.56
	Maffra	0.92	0.58	0.82	0.95	0.06	0.80	0.96	<0.05	0.60
	Stratford	0.90	0.68	0.82	0.92	0.41	0.78	0.91	<0.05	0.57
Morwell	Churchill	0.92	0.80	0.86	0.94	0.80	0.87	0.98	0.66	0.85
	Boolarra	0.90	0.80	0.85	0.90	0.81	0.86	0.92	0.75	0.86
	Jumbuk	0.90	0.81	0.86	0.90	0.80	0.87	0.93	0.74	0.86
	Morwell	1.00	0.08	0.83	1.10	0.62	0.87	0.98	0.44	0.86
	Traralgon South/ Hazelwood North	0.95	0.64	0.86	0.93	0.78	0.87	0.92	0.68	0.86
	Yinnar	0.90	0.80	0.85	0.91	0.78	0.87	0.91	0.73	0.86
Moe	Moe	0.92	0.35	0.80	0.94	0.57	0.82	0.91	0.49	0.82
	Newborough	0.88	0.58	0.79	0.90	0.63	0.82	0.89	0.72	0.83
	Trafalgar	0.90	0.50	0.80	0.92	0.61	0.82	0.92	0.70	0.83
	Yallourn North	0.89	0.55	0.79	0.90	0.68	0.82	0.88	0.74	0.83
	Thorpdale ⁵	0.88	0.54	0.79	0.89	0.61	0.81	0.90	0.72	0.82
	Yarragon	0.96	0.54	0.80	0.93	0.63	0.83	0.89	0.70	0.83
Sale	Sale/Wurruk	0.90	0.65	0.84	0.93	0.76	0.85	0.97	0.77	0.88
Traralgon	Traralgon	0.90	0.20	0.79	0.87	0.70	0.79	0.91	<0.05	0.80
Warragul	Drouin	1.00	0.80	0.90	1.10	0.73	0.92	1.07	0.65	0.85
	Rokeby/Buln Buln	1.00	0.79	0.90	1.10	0.79	0.92	1.13	0.64	0.86
	Warragul	1.00	0.79	0.90	1.10	0.57	0.93	1.12	0.57	0.84
	Warragul South	0.97	0.83	0.90	1.00	0.84	0.92	0.98	0.70	0.83

¹ = The average value calculated based on all monitoring conducted over the 2018-19 reporting period, including when dosing did not occur.

All fluoride dosing systems performed within requirements for the 2018-2019 reporting period. Overall system performance has improved compared to 2016-2017 & 2015-2016 reporting periods.

9.4.2 Actions taken in relation to non-compliance

All systems achieved compliance against the standard (no single sample concentration of fluoride in drinking water should exceed 1.5 mg/L, and the average level of fluoride should not exceed 1.0 mg/L).

All systems achieved an annual average minimum concentration above 0.6 mg/L for the reporting period.

9.4.3 Fluoride dosing systems performance and maintenance 2018-19

The Gippsland Water fluoride dosing systems upgrade program was completed during the 2018-19 year. Gippsland Water has now upgraded all fluoride dosing systems (from a dissolvable PVA bag process to a fully enclosed delivery system) to improve health and safety associated with the handling of a sodium fluoride powder.

- Traralgon

The fluoride dosing system at the Traralgon Water Treatment Plant was operational for the duration of the reporting period.

- Maffra

The fluoride dosing system at the Maffra Water Treatment Plant was operational for the duration of the reporting period.

- Warragul

The fluoride dosing system at the Warragul Water Treatment Plant was operational for the duration of the reporting period.

- Sale

The fluoride dosing system at the Sale Water Treatment Plant was operational for the duration of the reporting period.

- Morwell

The fluoride dosing system at the Morwell Water Treatment Plant was operational for the duration of the reporting period.

- Moe

The fluoride dosing system at the Moe Water Treatment Plant was operational during the reporting period.

Under the Code of Practice for Fluoridation of Drinking Water Supplies, Gippsland Water is required to notify the DHHS if the fluoride concentration in drinking water, measured at the fluoridation plant, is less than 0.6 mg/L for a continuous period of greater than 72 hours.

On one occasion during the reporting period, the fluoride system at Moe was turned off for 94 consecutive hours between 17/12/18 and 21/12/18. The system was shut down for routine maintenance (routine cleaning and replacement of the filter media) on the sodium fluoride saturation tank.

9.5 WATER TREATMENT PROJECTS AND PROGRAMS UNDERTAKEN

During the 2018-19 reporting period, Gippsland Water undertook a number of works, programs or projects to ensure that continual improvements were made to ensure the ongoing provision of safe drinking water to its customers. These included:

- ❑ treated water storage basins and tank condition assessments as part of the ongoing inspection, maintenance and cleaning program;
- ❑ ongoing water treatment plant filter upgrades and refurbishment program;
- ❑ installation and upgrades of remote disinfection sites;
- ❑ ongoing implementation of water reticulation mains air scouring program;
- ❑ ongoing replacement and upgrade of water quality on-line and field instrumentation;
- ❑ minor upgrade works across multiple sites that included replacement of high lift pumps (to transfer treated water from water treatment plant to system storages), upgrades of diesel generator points at all water treatment plants for alternative emergency power supply, and improvements to chemical storage bund enclosures; and
- ❑ catchment sanitary survey activities to manage microbial and water quality risks as part of our health based target risk assessment.




Figure 7: Disinfection dosing lance innovation – Disinfection system upgrade

Our Water Quality Technician team was the 2019 winner of the national WIOA Problem Accepted Solution Supplied (PASS) Award for the innovative design for a perforated large main dosing lance to improve disinfection.



Figure 8: Maffra, Mirboo North and Warragul Water Treatment Plant – Streaming Current control unit

Maffra, Mirboo North and Warragul Water Treatment Plant – Commissioning of Streaming Current Detector process control units to improve water treatment plant performance and reliability

Figure 9: Moe Water Treatment Plant – Transfer pipe upgrade

In early April 2019 a leak on the outlet pipework between the Moe WTP 22 ML clear water storage and the 0.5ML chlorine contact tank was identified. The compromised pipework is the only pipe that supplies the Moe System (24,000 customers). The pipe was replaced to ensure security of supply.






Figure 10: Heyfield Water Treatment Plant – Chemical dosing system

Heyfield Water Treatment Plant chemical dosing system upgraded to improve performance and reliability. Upgrade also included the replacement of the chlorine gas disinfection system with a sodium hypochlorite based disinfection system to improve safety.



Figure 11: Morwell water supply locality Ridge Reservoir project – Chemical dosing system

Ridge Reservoir remote disinfection site for water disinfection and removal of a safety risk and ongoing provision of safe drinking water.

Figure 12: Moe Water Treatment Plant – Off Specification Water Basin Clean and Reinstatement

Moe water treatment plant lagoon was desludged to provide additional storage capacity for off specification water reprocessing to ensure safe drinking water production occurs. Approximately 100m² of alum solid from the treatment off specification water reprocessing was removed.



Figure 13: Traralgon Water Treatment Plant – Filter Upgrade

Traralgon Water Treatment Plant upgrade of water treatment filter for improved water quality.



Figure 14: Water Quality – Water information Management System

Implementation of a water information management system (WIMS) to remove paper based systems for improved process, operational and compliance data management and reporting across all Water Quality Remote Disinfection Sites.



Gippsland Water Reticulation/ Water Quality



Disinfection Sites	North	South	East	West
	Duke Street (Rosedale) Chlorinator	Sanders Basin Chlorinator	Stratford (Avon River) Chlorinator	Kenny's Rd (Trafalgar) Chlorinator
	Rosedale Basin Chlorinator	Northways Basin Chlorinator	Stratford H/L Tank Chlorinator	Williamson's Rd (Yarragon) Chlorinator
	Hunter Rd (Traralgon) Chlorinator	Jeeralang Nth Rd Chlorinator	McAdams St Chlorinator	Warragul Sth Basin Chlorinator
	Blacks (Traralgon) Chlorinator	Mirboo North Chlorinator	Sandy Creek Rd Tanks Chlorinator	Drouin Chlorinator
	Rawson (Parkers Cnr) Trim Chlorinator	Billy's Creek Chlorinator	Boisdale Chlorinator	Darnum Disinfection
	Newborough Chlorinator	Clarks Storage (Warren Tce) Chlorinator	Toongabbie Basin Chlorinator	Drouin West Chlorinator
	Howletts Track Chlorinator	Boolarra Chlorinator		
	Yallourn W Chlorinator	Buckley's Hill Chlorinator		
		Brodribb Rd Chlorinator		
		Ridge Storage Basin Chlorinator		
Tanks & Basins Program	Western WTG	Central 1 WTG	Central 2 WTG	Eastern WTG
	Rawson	Traralgon	Mirboo North	Maffra
	Neerim South	Tyers	Morwell	Briagolong
	Willow Grove	Moe		Sale
	Warragul			Heyfield
				Seaspray
				Coongulla

Figure 15: Water Quality – Monitoring Instrumentation Upgrades

Upgrade of various water quality instruments (benchtop and on line) to manage water quality parameters for compliance with SDWA and process requirements. Implementation of a water information management system (WIMS) to remove paper based systems for improved process, operational and compliance data management and reporting across all Water Quality Remote Disinfection Sites



9.6 CATCHMENT PROJECTS AND PROGRAMS UNDERTAKEN

Gippsland Water engages with many different stakeholders regarding the protection of water quality within drinking water catchments.

We work closely with West Gippsland Catchment Management Authority (WGCMA) to preserve and improve the waterways and lakes ecosystems for the community, and to supply safe drinking water to our customers.

This year, we partnered with the WGCMA, local agronomists and local farmers in a program to keep nutrients and sediment on farms by turning run-off into an asset, contributing to productivity and improving the health of local waterways.

We also partnered with Baw Baw Shire Council and Wellington Shire Council to assess septic tank conditions within our drinking water catchments. The program aims to increase understanding of how well on-site waste is being managed in and around catchments as well as areas for future improvements.

Interactions regarding catchment issues with stakeholders is detailed in Table 19.

During the reporting period Gippsland water catchment projects have included:

- ❑ Land Use Options assessment for future use for the Moondarra Catchment;
- ❑ Desilting of Mirboo North raw water offtake.
- ❑ Finalisation of the 2nd round sanitary surveys on our highest risk level 4 catchments (Thomson & Macalister) will inform the final catchment declaration submission. This review is specifically focused on organic chemical monitoring and an enhanced review of our risk based monitoring program



Figure 16: Mirboo North Weir – Desilt clean-up activities

Programmed Mirboo North weir desilt activities to ensure raw water catchment remains operational year round.

Table 17: Gippsland Water locality water source and activities undertaken

Locality	Source water	Raw Water Storage	Water Storage Manager	Catchment Management Authority	Catchment Activity Interactions
Maffra	Macalister River	Lake Glenmaggie	Southern Rural Water	West Gippsland Catchment Management Authority	<ul style="list-style-type: none"> • Water Quality Risk Assessment – chemical (External) • Sanitary Survey • Domestic Wastewater Management Plan – resource funding • Assist with funding inspections of on-site waste treatment facilities (septics) • Ensure catchment water quality is considered in bushfire suppression activities (presence in local ICC) • Water Licence applications referrals – water quality assessments • Planning application assessments • Participate in Gippsland Strategic Bushfire Fuel Management Planning Project • Discussion with DELWP regarding future catchment declaration • Support Integrated Water Management Plan development
Stratford					
Boisdale					
Briagolong	Bore (Freestone Creek Aquifer)	N/A	Southern Rural Water	West Gippsland Catchment Management Authority	<ul style="list-style-type: none"> • Sanitary Survey • CSG baseline monitoring • On-site landholder engagement & risk assessment • Participate in Gippsland Strategic Bushfire Fuel Management Planning Project • Ensure catchment water quality is considered in bushfire suppression activities (presence in local ICC) • Planning application assessments • Domestic Wastewater Management Plan – resource funding • Domestic Wastewater Management Plan – resource funding • PFAS/PFOA monitoring

Table 17 (cont.): Gippsland Water locality water source

Locality	Source water	Raw Water Storage	Water Storage Manager	Catchment Management Authority	Catchment Activity Interactions
Morwell	Tyers River	Moondarra	Gippsland Water	West Gippsland Catchment Management Authority	<ul style="list-style-type: none"> • Moondarra Land Use Assessment • Sanitary Survey • Moondarra Fire Prevention Plan • Road Maintenance • Carp Biomass Survey • Participate in Gippsland Strategic Bushfire Fuel Management Planning Project • Ensure catchment water quality is considered in bushfire suppression activities (presence in local ICC) • Forestry Spray application program review
Boolarra					
Churchill					
Yinnar					
Jumbuk					
Traralgon South/Hazelwood North					
Tyers/Glengarry	Tyers River	Moondarra	Gippsland Water	West Gippsland Catchment Management Authority	<ul style="list-style-type: none"> • Moondarra Land Use Assessment • Sanitary Survey • Moondarra Fire Prevention Plan • Road Maintenance • Carp Biomass Survey • Participate in Gippsland Strategic Bushfire Fuel Management Planning Project • Ensure catchment water quality is considered in bushfire suppression activities (presence in local ICC) • Forestry Spray application program review
Rosedale					
Toongabbie					
Cowwarr					
Traralgon	Tyers River	Moondarra	Gippsland Water	West Gippsland Catchment Management Authority	<ul style="list-style-type: none"> • Moondarra Land Use Assessment • Sanitary Survey • Moondarra Fire Prevention Plan • Road Maintenance • Carp Biomass Survey • Participate in Gippsland Strategic Bushfire Fuel Management Planning Project • Ensure catchment water quality is considered in bushfire suppression activities (presence in local ICC) • Forestry Spray application program review

Table 17 (cont.): Gippsland Water locality water source

Locality	Source water	Raw Water Storage	Water Storage Manager	Catchment Management Authority	Catchment Activity Interactions
Warragul (including Nilma, Drouin East)	Pederson Weir (Tarago River) Tarago Reservoir - (supplementary supply)	Tarago Reservoir (supplementary supply)	Melbourne Water	West Gippsland Catchment Management Authority	<ul style="list-style-type: none"> Sanitary Survey Domestic Wastewater Management Plan – resource funding Assist with funding inspections of on-site waste treatment facilities (septics) Ensure catchment water quality is considered in bushfire suppression activities (presence in local ICC) Planning application assessments Participate in Gippsland Strategic Bushfire Fuel Management Planning Project Forestry Spray application program review Liaise with Melbourne Water
Warragul South					
Drouin					
Rokeyby/Buln Buln					
Coongulla/ Glenmaggie	Macalister River	Lake Glenmaggie	Southern Rural Water	West Gippsland Catchment Management Authority	<ul style="list-style-type: none"> Sanitary Survey Domestic Wastewater Management Plan – resource funding Assist with funding inspections of on-site waste treatment facilities (septics) Ensure catchment water quality is considered in bushfire suppression activities (presence in local ICC) Planning application assessments Participate in Gippsland Strategic Bushfire Fuel Management Planning Project Forestry Spray application program review
Rawson	Trigger Creek	Amours Basins	Gippsland Water	West Gippsland Catchment Management Authority	<ul style="list-style-type: none"> Sanitary Survey Participate in Gippsland Strategic Bushfire Fuel Management Planning Project Ensure catchment water quality is considered in bushfire suppression activities (presence in local ICC)
Erica					

Table 17 (cont.): Gippsland Water locality water source

Locality	Source water	Raw Water Storage	Water Storage Manager	Catchment Management Authority	Catchment Activity Interactions
Heyfield	Thomson River	Heyfield raw water storage	Gippsland Water	West Gippsland Catchment Management Authority	<ul style="list-style-type: none"> Sanitary Survey Domestic Wastewater Management Plan – resource funding Ensure catchment water quality is considered in bushfire suppression activities (presence in local ICC) Planning application assessments Participate in Gippsland Strategic Bushfire Fuel Management Planning Project Discussion with DELWP regarding future catchment declaration Forestry Spray application program review Liaise with Melbourne Water Water Quality Risk Assessment – chemical (External) Environmental flow Planning
Mirboo North	Little Morwell River	N/A	N/A	West Gippsland Catchment Management Authority	<ul style="list-style-type: none"> Weir Desilting Sanitary Survey Participate in Gippsland Strategic Bushfire Fuel Management Planning Project
Moe	Tanjil River and Narracan Creek	N/A	N/A	West Gippsland Catchment Management Authority	<ul style="list-style-type: none"> Sanitary Survey Domestic Wastewater Management Plan – resource funding Assist with funding inspections of on-site waste treatment facilities (septics) Ensure catchment water quality is considered in bushfire suppression activities (presence in local ICC) Planning application assessments Participate in Gippsland Strategic Bushfire Fuel Management Planning Project Forestry Spray application program review Arranging FertSmart program Environmental Flow planning Assist in provision of advice for waste treatment works for Industrial customer in catchment Water sampling and analysis of waste system performance for Industrial customer
Newborough					
Yallourn North					
Trafalgar					
Yarragon					
Darnum					

Table 17 (cont.): Gippsland Water locality water source

Locality	Source water	Raw Water Storage	Water Storage Manager	Catchment Management Authority	Catchment Activity / Interactions
Neerim South	Tarago River	Tarago Reservoir	Melbourne Water	West Gippsland Catchment Management Authority	<ul style="list-style-type: none"> Sanitary Survey Domestic Wastewater Management Plan – resource funding Assist with funding inspections of on-site waste treatment facilities (septics) Ensure catchment water quality is considered in bushfire suppression activities (presence in local ICC) Planning application assessments Participate in Gippsland Strategic Bushfire Fuel Management Planning Project Forestry Spray application program review Liaise with Melbourne Water
Noojee					
Sale / Wurruk	Bore (Boisdale Aquifer)	N/A	Southern Rural Water	West Gippsland Catchment Management Authority	<ul style="list-style-type: none"> Sanitary Survey CSG baseline monitoring PFAS/PFOA monitoring Participate in Gippsland Strategic Bushfire Fuel Management Planning Project Ensure catchment water quality is considered in bushfire suppression activities (presence in local ICC)
Seaspray	Merrimans Creek	Seaspray raw water storage	Gippsland Water	West Gippsland Catchment Management Authority	<ul style="list-style-type: none"> Sanitary Survey CSG baseline monitoring Weir desilting Assist with funding inspections of on-site waste treatment facilities (septics) PFAS/PFOA monitoring Participate in Gippsland Strategic Bushfire Fuel Management Planning Project Ensure catchment water quality is considered in bushfire suppression activities (presence in local ICC)
Thorpdale (water carting from Moe locality)	Tanjil River and Narracan Creek (September 2015 - ongoing)	N/A	N/A	West Gippsland Catchment Management Authority	<ul style="list-style-type: none"> Refer to Moe Locality

Table 17 (cont.): Gippsland Water locality water source

Locality	Source water	Raw Water Storage	Water Storage Manager	Catchment Management Authority	Catchment Activity / Interactions
Willow Grove	Tanjil River	Blue Rock Lake	Southern Rural Water	West Gippsland Catchment Management Authority	<ul style="list-style-type: none"> • Revegetation of stormwater gully (Blue Rock Reservoir) • Integrated Water Management Projects • Sanitary Survey • Participate in Gippsland Strategic Bushfire Fuel Management Planning Project • Ensure catchment water quality is considered in bushfire suppression activities (presence in local ICC)

9.7 OTHER ALGAE, PATHOGEN, CHEMICAL OR SUBSTANCE NOT SPECIFIED THAT MAY POSE A RISK TO HUMAN HEALTH

9.7.1 Overall results

During the reporting period, the corporation monitored for the following health-related aspects of the drinking water supplied to customer taps. Table 13 lists the parameters and the frequency of samples taken across all localities, comparing the results to the ADWG and the health-based guideline value.

Table 18: Other sampled parameter results for all localities in 2018-19

Parameter	Frequency of sampling	2018-19 No. of Samples	2018-19 Maximum Value Recorded for All Localities (mg/L)	2017-18 Maximum Value Recorded for All Localities (mg/L)	2016-17 Maximum Value Recorded for All Localities (mg/L)	Health Based Guideline value (mg/L)	Result
Nitrite	Weekly*/6 Monthly	449	0.018	0.5	0.7	< 3	All results below ADWG health guideline values
Mercury	Quarterly	302	0.0001	0.0004	<0.0001	< 0.001	
Chromium	Quarterly	157	<0.001	0.002	<0.001	< 0.05	
Cadmium	Quarterly	157	<0.0002	0.0003	<0.0002	< 0.002	
Nitrate	Weekly*/Quarterly	303	1.4	1.2	1.5	< 50	
Nickel	Annually	52	0.004	0.01	0.006	< 0.02	
Arsenic	Annually/Quarterly	131	<0.001	<0.001	<0.001	< 0.01	
Cyanide	Annually	36	<0.005	<0.005	<0.002	< 0.08	
Selenium	Annually/Quarterly	131	<0.001	<0.001	<0.001	< 0.01	
Beryllium	Annually/6 Monthly	88	<0.01	<0.01	<0.001	< 0.06	
Chloryl Hydrate	Monthly	216	0.017	0.016	0.030	< 0.1	
2, 4-Dichlorophenoxy acetic acid	Monthly	216	<0.01	<0.01	<0.01	< 0.03	
Nitrosodimethylamine	Monthly**	24	0.000014	0.000017	0.000012	< 0.0001	
2,4,6-Trichlorophenol	Monthly***	208	<0.001	<0.001	<0.001	< 0.02	
2,4-Dichlorophenol	Monthly***	208	<0.001	<0.001	<0.001	< 0.2	
2- Chlorophenol	Monthly***	208	<0.001	<0.001	<0.001	< 0.3	
Pentachlorophenol	Monthly	216	<0.001	<0.001	<0.001	< 0.01	
Parameter	Frequency of sampling	2018-19 No. of Samples	2018-19 Maximum Value Recorded for All Localities (mg/L)	2017-18 Maximum Value Recorded for All Localities (mg/L)	2016-17 Maximum Value Recorded for All Localities (mg/L)	Aesthetic Based Guideline value (mg/L)	Result
Chloride	Annually/Quarterly	197	180	150	160	<250	All results below ADWG health guideline values
Zinc	Annually	52	0.018	0.17	0.010	<3	
Hardness (CaCO ₃)	Annually/Quarterly	131	130	120	120	<200	
Total dissolved solids	Annually/Quarterly	132	380	330	340	<600	
Silica	Annually/Quarterly	131	15	15	16	<80	
Sulphate	Annually/Quarterly	143	63	45	23	<250	

*- Weekly monitoring undertaken on chloraminated systems

** - Monthly monitoring undertaken on chloraminated systems

*** - Frequency Increased from quarterly to monthly during reporting period

Monitoring for other parameters such as radiological, pesticides, protozoan organisms is conducted routinely. A complete list of raw water parameters monitored is contained in Appendix 1. Additional monitoring is performed on a risk basis and as the need arises.

Blue Green Algae (BGA) monitoring is undertaken across Gippsland Water storages based on visual and water quality triggers. Major raw water supply/storages are routinely monitored for BGA as part of the routine catchment monitoring program. The frequency of sampling is determined by the assessed risk and historical bloom occurrences.

For water storages not managed by Gippsland Water, the Water Storage Manager (Melbourne Water – Tarago, Southern Rural Water – Blue Rock and Lake Glenmaggie) undertakes monitoring and advised Gippsland Water of the results in accordance with their respective algae management plans.

Table 19: Routine BGA monitoring for raw water supplies in 2018-19 (samples per month collected)

Location	Jul '18	Aug '18	Sept '18	Oct '18	Nov '18	Dec '18	Jan '19	Feb '19	Mar '19	Apr '19	May '19	Jun '19
Maffra Weir	2	2	2	4	5	4	5	4	4	4	2	2
Heyfield Raw Water Storage	2	2	2	4	5	4	5	4	4	4	2	2
Thorpdale Raw Water Storage	No longer in use (drained)											
Neerim South Tarago Reservoir	1	1	1	1	1	1	1	1	1	1	1	1
Rawson Amours Basin	1	1	1	1	1	1	1	1	1	1	1	1
Seaspray Raw Water Storage	2	2	2	4	5	4	5	4	4	4	2	2
Seaspray – Merriman Creek	1	1	1	2	2	2	2	2	2	2	1	1
Blue Rock Lake (Southern Rural Water BGA Program)	Southern Rural Water (SRW) BGA Monitoring Program											
Willow Grove WTP Inlet - Blue Rock	1	1	1	1	1	1	1	1	1	1	1	1
Lake Glenmaggie (Southern Rural Water BGA Program)	Southern Rural Water (SRW) BGA Monitoring Program											
Coongulla WTP Inlet – Lake Glenmaggie	2	2	2	4	5	4	5	4	4	4	2	2
Tarago Reservoir (Melbourne Water BGA Program)	Melbourne Water BGA Monitoring Program											
Warragul WTP Inlet – Tarago Reservoir	1	1	1	1	1	1	1	1	1	1	1	1
Moondarra Surface	1	1	1	1	1	1	1	1	1	1	1	1
Moondarra pipeline	1	1	1	1	1	1	1	1	1	1	1	1
Moondarra Upper reaches	<i>As required</i>											

During the reporting period, although there were algae and blue green algae blooms, none of these impacted the water treatment process or the production of safe drinking water.

9.7.2 Manganese

Manganese can be naturally present in raw water supplies as either a soluble or insoluble form. When concentrations exceed the aesthetic guideline of 0.1 mg/L, manganese can create unacceptable tastes in water, as well as stain fixtures and laundry. The ADWG guideline value is measured against the health guideline value of 0.5 mg/L in ADWG. Gippsland Water sites achieved 100% manganese ADWG guideline value.

Table 20: Manganese results for all localities in 2018-19

Locality	Frequency of Sampling	No. of Samples	Average# (mg/L)	Max (mg/L)	Min (mg/L)	Drinking Water Quality Standard Met (ADWG) (Yes/No)^
Boisdale	Monthly	12	0.002	0.006	<0.001	Yes
Boolarra	Weekly	64	N/A*	<0.001	<0.001	Yes
Briagolong	Weekly	64	N/A*	<0.001	<0.001	Yes
Churchill	Monthly	12	N/A*	<0.001	<0.001	Yes
Coongulla/Glenmaggie	Weekly	64	0.002	0.006	<0.001	Yes
Cowwarr	Monthly	12	N/A*	<0.001	<0.001	Yes
Drouin	Monthly	12	0.002	0.010	<0.001	Yes
Erica	Monthly	12	0.008	0.013	0.004	Yes
Heyfield	Weekly	64	0.007	0.016	0.002	Yes
Jumbuk	Monthly	12	N/A*	<0.001	<0.001	Yes
Maffra	Weekly	64	0.008	0.080	<0.001	Yes
Mirboo North	Weekly	64	0.002	0.011	<0.001	Yes
Moe	Weekly	65	0.005	0.019	<0.001	Yes
Morwell	Weekly	104	0.002	0.010	<0.001	Yes
Neerim South	Weekly	64	0.017	0.046	0.006	Yes
Newborough	Monthly	12	0.001	0.002	<0.001	Yes
Noojee	Monthly	12	0.016	0.031	0.006	Yes
Rawson	Weekly	64	0.011	0.027	0.004	Yes
Rokeyby/Buln Buln	Monthly	12	0.002	0.003	<0.001	Yes
Rosedale	Monthly	12	0.001	0.001	<0.001	Yes
Sale/Wurruk	Weekly	64	0.002	0.005	<0.001	Yes
Seaspray	Weekly	64	0.005	0.009	0.002	Yes
Stratford	Monthly	12	0.001	0.005	<0.001	Yes
Thorpdale	Weekly	64	0.001	0.002	<0.001	Yes
Toongabbie	Monthly	12	0.001	0.001	<0.001	Yes
Trafalgar	Weekly	64	0.002	0.005	<0.001	Yes
Traralgon	Weekly	64	0.001	0.007	<0.001	Yes
Traralgon South/Hazelwood North	Monthly	12	0.001	0.001	<0.001	Yes
Tyers/Glengarry	Weekly	63	0.003	0.007	<0.001	Yes
Warragul	Weekly	114	0.002	0.011	<0.001	Yes
Warragul South	Monthly	12	0.001	0.002	<0.001	Yes
Willow Grove	Weekly	64	0.003	0.007	<0.001	Yes
Yallourn North	Monthly	12	0.002	0.007	<0.001	Yes
Yarragon	Weekly	64	0.001	0.004	<0.001	Yes
Yinnar	Monthly	12	0.001	0.001	<0.001	Yes

*= average unable to be calculated as all results for reporting period were below detection level

#= average values calculated using the detection limit value for sample results showing less than detection limit.

^= Based on the maximum value being below the ADWG guideline health limit of 0.5 mg/L.

9.7.3 Actions taken in relation to non-compliance

All localities complied with this water quality parameter.

9.7.4 Lead

Lead can be present in drinking water as a result of dissolution from natural sources or from household plumbing. Based on health considerations in the ADWG guidelines, concentrations of lead in drinking water should not exceed 0.01 mg/L. Gippsland Water sites achieved 100% ADWG guideline value against lead guideline values for all customer tap sites.

Table 21: Lead results for all localities in 2018-19

Locality	Frequency of Sampling	No. of Samples	Average# (mg/L)	Max (mg/L)	Min (mg/L)	Drinking Water Quality Standard Met (ADWG) (Yes/No)^
Boisdale	Quarterly	4	N/A*	<0.001	<0.001	Yes
Boolarra	Quarterly	4	N/A*	<0.001	<0.001	Yes
Briagolong	Quarterly	4	0.001	0.001	<0.001	Yes
Churchill	Quarterly	4	N/A*	<0.001	<0.001	Yes
Coongulla/Glenmaggie	Quarterly	4	N/A*	<0.001	<0.001	Yes
Cowwarr	Quarterly	4	N/A*	<0.001	<0.001	Yes
Drouin	Quarterly	4	N/A*	<0.001	<0.001	Yes
Erica	Quarterly	4	N/A*	<0.001	<0.001	Yes
Heyfield	Quarterly	4	N/A*	<0.001	<0.001	Yes
Jumbuk	Quarterly	4	N/A*	<0.001	<0.001	Yes
Maffra	Quarterly	4	N/A*	<0.001	<0.001	Yes
Mirboo North	Quarterly	4	N/A*	<0.001	<0.001	Yes
Moe	Quarterly	4	N/A*	<0.001	<0.001	Yes
Morwell	Quarterly	4	N/A*	<0.001	<0.001	Yes
Neerim South	Quarterly	4	N/A*	<0.001	<0.001	Yes
Newborough	Quarterly	4	N/A*	<0.001	<0.001	Yes
Noojee	Quarterly	4	N/A*	<0.001	<0.001	Yes
Rawson	Quarterly	4	N/A*	<0.001	<0.001	Yes
Rokeby/Buln Buln	Quarterly	4	N/A*	<0.001	<0.001	Yes
Rosedale	Quarterly	4	N/A*	<0.001	<0.001	Yes
Sale/Wurruk	Quarterly	4	N/A*	<0.001	<0.001	Yes
Seaspray	Quarterly	4	N/A*	<0.001	<0.001	Yes
Stratford	Quarterly	4	N/A*	<0.001	<0.001	Yes
Thorpdale	Quarterly	4	N/A*	<0.001	<0.001	Yes
Toongabbie	Quarterly	4	N/A*	<0.001	<0.001	Yes
Trafalgar	Quarterly	4	N/A*	<0.001	<0.001	Yes
Traralgon	Quarterly	4	N/A*	<0.001	<0.001	Yes
Traralgon South/Hazelwood North	Quarterly	4	N/A*	<0.001	<0.001	Yes
Tyers/Glengarry	Quarterly	4	N/A*	<0.001	<0.001	Yes
Warragul	Monthly	16	N/A*	<0.001	<0.001	Yes
Warragul South	Quarterly	4	N/A*	<0.001	<0.001	Yes
Willow Grove	Quarterly	4	N/A*	<0.001	<0.001	Yes
Yallourn North	Quarterly	4	N/A*	<0.001	<0.001	Yes
Yarragon	Quarterly	4	N/A*	<0.001	<0.001	Yes
Yinnar	Quarterly	4	N/A*	<0.001	<0.001	Yes

*= average unable to be calculated as all results for reporting period were below detection level

#= average values calculated using the detection limit value for sample results showing less than detection limit.

^= Based on the maximum value being below the ADWG guideline health limit of 0.01 mg/L.

9.7.5 Actions taken in relation to non-compliance

All localities complied with this water quality parameter.

9.7.6 Copper

Copper is present in raw water supplies at very low concentrations. Copper can be found in higher concentrations in drinking water as a result of corrosion of copper pipes and fittings. Based on health considerations in the ADWG guideline, concentrations of copper in drinking water should not exceed 2 mg/L. The aesthetic guideline value is 1 mg/L. Gippsland Water sites achieved 100% ADWG guideline value against both copper guideline values.

Table 22: Copper results for all localities in 2018-19

Locality	Frequency of Sampling	No. of Samples	Average# (mg/L)	Max (mg/L)	Min (mg/L)	Drinking Water Quality Standard Met (ADWG) (Yes/No)^
Boisdale	Quarterly	4	0.005	0.006	0.003	Yes
Boolarra	Quarterly	4	0.003	0.004	0.002	Yes
Briagolong	Quarterly	4	0.007	0.013	0.003	Yes
Churchill	Quarterly	4	0.003	0.007	<0.001	Yes
Coongulla/Glenmaggie	Quarterly	4	0.008	0.013	0.001	Yes
Cowwarr	Quarterly	4	0.003	0.007	0.001	Yes
Drouin	Quarterly	4	0.009	0.022	0.004	Yes
Erica	Quarterly	4	0.008	0.010	0.005	Yes
Heyfield	Quarterly	4	0.021	0.046	0.005	Yes
Jumbuk	Quarterly	4	0.007	0.014	0.002	Yes
Maffra	Quarterly	4	0.016	0.040	0.002	Yes
Mirboo North	Quarterly	4	0.010	0.012	0.006	Yes
Moe	Quarterly	4	0.033	0.082	<0.001	Yes
Morwell	Quarterly	4	0.005	0.009	0.002	Yes
Neerim South	Quarterly	4	0.009	0.010	0.007	Yes
Newborough	Quarterly	4	0.038	0.086	0.002	Yes
Noojee	Quarterly	4	0.005	0.009	0.002	Yes
Rawson	Quarterly	4	0.012	0.024	0.007	Yes
Rokeby/Buln Buln	Quarterly	4	0.006	0.008	0.003	Yes
Rosedale	Quarterly	4	0.002	0.002	<0.001	Yes
Sale/Wurruk	Quarterly	4	0.023	0.040	0.007	Yes
Seaspray	Quarterly	4	0.023	0.031	0.006	Yes
Stratford	Quarterly	4	0.009	0.017	0.003	Yes
Thorpdale	Quarterly	4	0.002	0.003	<0.001	Yes
Toongabbie	Quarterly	4	0.010	0.019	0.005	Yes
Trafalgar	Quarterly	4	0.005	0.007	<0.001	Yes
Traralgon	Quarterly	4	0.011	0.034	0.003	Yes
Traralgon South/Hazelwood North	Quarterly	4	0.004	0.008	0.002	Yes
Tyers/Glengarry	Quarterly	4	0.020	0.027	0.010	Yes
Warragul	Monthly/Qrtly	16	0.001	0.004	<0.001	Yes
Warragul South	Quarterly	4	0.007	0.010	0.002	Yes
Willow Grove	Quarterly	4	0.004	0.005	0.002	Yes
Yallourn North	Quarterly	4	0.021	0.060	0.002	Yes
Yarragon	Quarterly	4	0.003	0.005	<0.001	Yes
Yinnar	Quarterly	4	0.003	0.004	<0.001	Yes

*= average unable to be calculated as all results for reporting period were below detection level

#= average values calculated using the detection limit value for sample results showing less than detection limit.

^= Based on the maximum value being below the ADWG guideline health limit of 2 mg/L.

9.7.7 Actions taken in relation to non-compliance

All localities complied with this water quality parameter.

9.8 AESTHETICS

9.8.1 pH results

In addition to the monitoring of parameters to determine compliance against the SDWA regulations, pH is routinely monitored in the reticulation system. The ADWG guidelines suggest that the drinking water be between pH 6.5 and pH 8.5. The pH results for all towns are provided below.

Table 23: pH results for all localities in 2018-19

Locality	Frequency of Sampling	No. of Samples	Average (units)	Max (units)	Min (units)	Drinking Water Aesthetic Operating Range Met (ADWG) (Yes/No) [^]
Boisdale	Weekly	52	7.5	7.7	7.2	Yes
Boolarra	Weekly	52	7.4	7.9	7.2	Yes
Briagolong	Weekly	52	7.0	7.2	6.9	Yes
Churchill	Weekly	52	7.3	8.4	7.0	Yes
Coongulla/Glenmaggie	Weekly	52	7.7	8.5	7.3	Yes
Cowwarr	Weekly	52	7.7	8.0	7.1	Yes
Drouin	Weekly	52	7.2	7.5	7.0	Yes
Erica	Weekly	52	7.5	8.4	6.8	Yes
Heyfield	Weekly	52	7.2	7.8	7.0	Yes
Jumbuk	Weekly	52	7.3	7.5	7.0	Yes
Maffra	Weekly	52	7.2	7.7	6.8	Yes
Mirboo North	Weekly	52	7.3	7.7	7.1	Yes
Moe	Weekly	52	7.1	7.6	6.6	Yes
Morwell	Weekly	52	7.2	7.6	6.9	Yes
Neerim South	Weekly	52	7.5	7.9	7.1	Yes
Newborough	Weekly	52	7.1	7.4	6.6	Yes
Noojee	Weekly	52	8.0	8.6	7.5	No
Rawson	Weekly	52	7.2	8.2	6.7	Yes
Rokeby/Buln Buln	Weekly	52	7.2	7.6	7.0	Yes
Rosedale	Weekly	52	7.7	9.0	7.2	No
Sale/Wurruk	Weekly	52	7.2	7.5	6.9	Yes
Seaspray	Weekly	52	7.2	7.8	6.8	Yes
Stratford	Weekly	52	7.4	7.6	7.1	Yes
Thorpdale	Weekly	52	8.2	9.0	7.5	No
Toongabbie	Weekly	52	7.2	7.4	7.0	Yes
Trafalgar	Weekly	52	7.3	8.3	7.1	Yes
Traralgon	Weekly	52	7.1	7.8	6.9	Yes
Traralgon South/Hazelwood North	Weekly	52	7.3	8.3	7.0	Yes
Tyers/Glengarry	Weekly	52	7.3	8.3	6.8	Yes
Warragul	Weekly	105	7.4	7.8	7.0	Yes
Warragul South	Weekly	52	7.4	8.1	7.1	Yes
Willow Grove	Weekly	52	8.0	8.5	7.7	Yes
Yallourn North	Weekly	52	7.1	7.4	6.9	Yes
Yarragon	Weekly	52	8.1	10.2	7.2	No
Yinnar	Weekly	52	7.4	7.9	7.1	Yes

[^]= Based on the minimum and maximum values being within the ADWG guideline aesthetic operating range of 6.5 – 8.5.

9.8.2 Actions taken in relation to non-compliance

Some systems (such as Noojee, Rosedale, Toongabbie and Yarragon) have experienced elevated pH values as a result of the residence time of water in the reticulation main. Water in contact with the cement-lined pipes will increase in pH in parts of the reticulation network. Reduced flushing

programs due to permanent water saving rules in place also contribute to higher pH values. All average pH results were within the range of 6.5 to 8.5.

ADWG states that cement mortar lined pipes can significantly increase the pH and a value up to 9.2 may be tolerated provided monitoring indicates no deterioration in the microbiological quality. No deterioration in the microbiological quality of the water was observed.

9.8.3 Iron results

Iron can become apparent in taste in water at about 0.3 mg/L and above. High concentrations can give water a rust-brown appearance and cause staining of laundry and plumbing fittings. Based on aesthetic considerations the concentration in the ADWG guidelines of iron in drinking water should not exceed 0.3 mg/L, however no health-based guideline value has been set for iron. Most sites achieved 100% ADWG guideline value against the aesthetic iron guideline value.

Table 24: Iron results for all localities in 2018-19

Locality	Frequency of Sampling	No. of Samples	Average [#] (mg/L)	Max (mg/L)	Min (mg/L)	Drinking Water Quality Standard Met (ADWG) (Yes/No)
Boisdale	Monthly	12	0.01	0.03	<0.01	Yes
Boolarra	Weekly	64	0.04	0.08	0.02	Yes
Briagolong	Weekly	64	0.01	0.02	<0.01	Yes
Churchill	Monthly	12	0.03	0.13	<0.01	Yes
Coongulla/Glenmaggie	Weekly	64	0.02	0.04	<0.01	Yes
Cowwarr	Monthly	12	0.01	0.02	<0.01	Yes
Drouin	Monthly	12	0.01	0.04	<0.01	Yes
Erica	Monthly	12	0.07	0.15	0.03	Yes
Heyfield	Weekly	64	0.01	0.01	<0.01	Yes
Jumbuk	Monthly	12	0.02	0.04	<0.01	Yes
Maffra	Weekly	64	N/A [*]	0.01	<0.01	Yes
Mirboo North	Weekly	64	0.01	0.05	<0.01	Yes
Moe	Weekly	65	0.01	0.04	<0.01	Yes
Morwell	Weekly	104	0.01	0.04	<0.01	Yes
Neerim South	Weekly	64	0.02	0.34	<0.01	No
Newborough	Monthly	12	0.01	0.02	<0.01	Yes
Noojee	Monthly	12	0.03	0.05	0.02	Yes
Rawson	Weekly	64	0.03	0.06	0.01	Yes
Rokeby/Buln Buln	Monthly	12	0.01	0.05	<0.01	Yes
Rosedale	Monthly	12	0.01	0.03	<0.01	Yes
Sale/Wurruk	Weekly	64	0.01	0.04	<0.01	Yes
Seaspray	Weekly	64	0.05	0.25	0.01	Yes
Stratford	Monthly	12	0.01	0.01	<0.01	Yes
Thorpdale	Weekly	64	0.03	0.06	0.01	Yes
Toongabbie	Monthly	12	N/A [*]	<0.01	<0.01	Yes
Trafalgar	Weekly	64	0.01	0.04	<0.01	Yes
Traralgon	Weekly	64	0.01	0.15	<0.01	Yes
Traralgon South/Hazelwood North	Monthly	12	0.01	0.03	<0.01	Yes
Tyers/Glengarry	Weekly	64	0.04	0.10	<0.01	Yes
Warragul	Weekly	114	0.01	0.05	<0.01	Yes
Warragul South	Monthly	12	0.01	0.02	<0.01	Yes
Willow Grove	Weekly	64	0.01	0.03	<0.01	Yes
Yallourn North	Monthly	12	0.04	0.15	<0.01	Yes
Yarragon	Weekly	64	0.01	0.04	<0.01	Yes
Yinnar	Monthly	12	0.03	0.08	<0.01	Yes

*= average unable to be calculated as all results for reporting period were below detection level

#= average values calculated using the detection limit value for sample results showing less than detection limit.

^= Based on the maximum value being below the ADWG guideline aesthetic limit of 0.3 mg/L.

9.8.4 Actions taken in relation to non-compliance

Neerim South failed to comply with the ADWG Aesthetic Guideline value for iron on one occasion during the reporting period. This was caused by a build-up of sediment within the system. Cleaning of the transfer main and distribution system is scheduled to occur during 2019-2020.

9.9 ANALYSIS OF RESULTS

Comparison to previous years

For the 2018-2019 reporting period, all samples analysed complied with the relevant water quality standards. The water quality standards required under the SDWR have been represented as trend data over three financial years. This information allows for a comparison of data for the major towns.

An analysis by the percentage of water sampling localities where the drinking water complied with each of the health based parameters, over three reporting periods, is shown below. The table also shows an analysis of the percentage of customers supplied with drinking water that complied with the standards.

Table 25: Compliance by locality and population

Parameter	Percentage by Locality			Percentage by Population		
	2016-17	2017-18	2018-19	2016-17	2017-18	2018-19
Aluminum	100%	100%	100%	100%	100%	100%
Chloroacetic Acid	100%	100%	100%	100%	100%	100%
Dichloroacetic Acid	100%	100%	100%	100%	100%	100%
<i>E. coli</i>	100%	100%	100%	100%	100%	100%
Trichloroacetic Acid	100%	100%	100%	100%	100%	100%
Trihalomethanes	100%	100%	100%	100%	100%	100%
Turbidity	100%	100%	100%	100%	100%	100%
Nitrite	100%	100%	100%	100%	100%	100%
Nitrate	100%	100%	100%	100%	100%	100%
Fluoride	100%	100%	100%	100%	100%	100%
Mercury	100%	100%	100%	100%	100%	100%
Chromium	100%	100%	100%	100%	100%	100%
Cadmium	100%	100%	100%	100%	100%	100%
Nickel	100%	100%	100%	100%	100%	100%
Arsenic	100%	100%	100%	100%	100%	100%
Selenium	100%	100%	100%	100%	100%	100%
Beryllium	100%	100%	100%	100%	100%	100%
Copper	100%	100%	100%	100%	100%	100%
Barium	100%	100%	100%	100%	100%	100%
Lead	100%	100%	100%	100%	100%	100%
Manganese	100%	100%	100%	100%	100%	100%
Cyanide	100%	100%	100%	100%	100%	100%
Selenium	100%	100%	100%	100%	100%	100%
Molybdenum	100%	100%	100%	100%	100%	100%
Acrylamide	100%	100%	100%	100%	100%	100%
Boron	100%	100%	100%	100%	100%	100%
Chloryl Hydrate	100%	100%	100%	100%	100%	100%
2, 4-Dichlorophenoxy acetic acid	100%	100%	100%	100%	100%	100%
Nitrosodimethylamine	100%	100%	100%	100%	100%	100%
2,4,6-Trichlorophenol	100%	100%	100%	100%	100%	100%
2,4-Dichlorophenol	100%	100%	100%	100%	100%	100%
2- Chlorophenol	100%	100%	100%	100%	100%	100%
Pentachlorophenol	100%	100%	100%	100%	100%	100%

Results for all listed tests for all localities maintained compliance during the 2018-19 reporting period.

This page intentionally left blank

10 UNDERTAKINGS UNDER SECTION 30 OF THE SDWA

Gippsland Water has no undertakings relevant to the 2018-19 reporting year.

11 EXEMPTIONS UNDER SECTION 20 OF THE SDWA

Gippsland Water has no exemptions relevant to the 2018-19 reporting year.

12 VARIATION IN AESTHETIC STANDARDS

Gippsland Water has no variations in aesthetic standards sought under section 19 of the SDWA.

13 REGULATED WATER

Gippsland Water does not manage any regulated water supplies.

14 GLOSSARY OF TERMS

Table 26: Glossary of terms

ADWG	<i>Australian Drinking Water Guidelines 2011</i> prepared by National Health and Medical Research Council that details a framework for the management of drinking water.
DHHS	Department of Health and Human Services.
CCP	A physical point in treatment processes that can be controlled either by SCADA, or manually, and has a significant impact on water quality.
Detection limit	The lowest concentration of analytical parameter in the sample that can be detected by the process laboratory.
Drinking Water Supply systems	Towns supplied with water from a common water source (WTP, supply mains and reticulation pipe-work).
<i>E. coli</i>	<i>Escherichia coli</i> .
Locality	Under the SDWR, a specified area that is supplied with drinking water by a water supplier.
mg/L	Milligram per litre.
NHMRC	National Health and Medical Research Council.
NTU	Nephelometric Turbidity Units.
Properties	A registered customer connection to the drinking water supply.
RMP	Risk Management Plan.
SCADA system	A Supervisory Control And Data Acquisition (SCADA) system consists of human-machine interface, computerised logics, telemetry communication system, electronically actuated instruments and sensors. SCADA allows remote control and monitor of all key processes

SDWA	<i>Safe Drinking Water Act 2003</i> Act No.46/2003.
SDWR	Safe Drinking Water Regulations 2015 S.R No.88/2015.
Source Water	Raw water supply for town, prior to treatment.
THM	Trihalomethane.
WSAA	Water Services Association Australia.
WTP	A facility where raw water is directed through various treatment processes and produces treated water fit for human consumption
100mL	100 millilitres.
<	Less than.
>	Greater than.
≤	Less than or equal to.
≥	Greater than or equal to.

15 FURTHER INFORMATION

Customers and members of the public may access drinking water quality data by contacting Gippsland Water on 1800 050 500 or visiting www.gippswater.com.au.

16 REFERENCES

National Health and Medical Research Council. *Australian Drinking Water Guidelines 2011*.
Web address www.nhmrc.gov.au

Department of Health and Human Services - Guidance: Water quality annual report Section 26 of the Safe Drinking Water Act 2003 Regulations 16 and 17 of the Safe Drinking Water Regulations 2015

Safe Drinking Water Act (2003) No.46/2003

Safe Drinking Water Regulations (2015) S.R No.88/2015

Health (Fluoridation) Act (1973)

Code of Practice for Fluoridation of Drinking Water Supplies; *Second Edition (2018)*

This page intentionally left blank

APPENDIX 1: RAW WATER MONITORING

Locality	Source water	Nature of other raw water monitoring programs		
		Weekly/Fortnightly	Monthly	Annual/Quarterly
Morwell Churchill Yinnar Jumbuk Boolarra Traralgon South/ Hazelwood North	Moondarra Reservoir via Tyers River	Physicals <ul style="list-style-type: none"> Absorbance (254nm) Colour True (465nm) Dissolved Oxygen SUVA (245nm) Turbidity Electrical Conductivity @25°C pH 	Physicals <ul style="list-style-type: none"> Alkalinity Bicarbonate as CaCO₃ Alkalinity Total as CaCO₃ Dissolved Organic Carbon (DOC) Total Organic Carbon (TOC) Total Dissolved Solids (TDS) SUVA (245nm) Chlorophyll a 	Physicals* <ul style="list-style-type: none"> Total Dissolved Solids (TDS) Suspended Solids Chemical inorganic <ul style="list-style-type: none"> Cyanide Dissolved Organic Carbon (DOC) Total Organic Carbon (TOC) Bromide Fluoride
Traralgon				
Tyers/Glengarry Rosedale Cowwarr Toongabbie				
Maffra	Macalister River	Microbiological <ul style="list-style-type: none"> <i>Escherichia coli</i> Total Coliforms Heterotrophic Plate Count 	Chemical inorganic <ul style="list-style-type: none"> Ammonia as N Bromide Chloride Fluoride Nitrate as N Nitrite as N Organic Nitrogen as N Phosphorous, Reactive as P Phosphorous Total as N Sulphate Total Kjeldahl Nitrogen as N Total Nitrogen as N 	Metals* <ul style="list-style-type: none"> Aluminium Total Arsenic Total Selenium Cadmium Total Copper Total Lead Total Mercury Zinc Total
Stratford				
Boisdale				
Briagolong	Bore (Freestone Creek Aquifer)	Metals* <ul style="list-style-type: none"> Iron Total Manganese Total Mercury 	Biological <ul style="list-style-type: none"> Algae Blue Green Algae (sampling frequency may vary depending on the season and results received)	Radiological <ul style="list-style-type: none"> Gross Alpha Activity Gross Beta Activity
Warragul (including Nilma, Darnum, Drouin East)	Pederson Weir (Tarago River) Tarago Reservoir - (supplementary supply)			
Warragul South				
Drouin				
Rokeby/Buln Buln	Macalister River	Microbiological <ul style="list-style-type: none"> <i>Cryptosporidium spp</i> <i>Giardia spp</i> 		
Coongulla/ Glenmaggie				
Rawson				
Erica	Trigger Creek			

Locality	Source water	Nature of other raw water monitoring programs		
		Weekly/Fortnightly	Monthly	Annual/Quarterly
Heyfield	Thomson River			<u>Pesticides, Herbicides and Chemical Organics**</u> <ul style="list-style-type: none"> • 2,4,5-T (Herbicide) • 2,4,5-Tp (Silvex) • 2,4,6-T • 2,4-D • 2,4-Db • 2,4-Dp • 2,6-D • 3-Hydroxy Carbofuran • 4-Cpa • 4 Chlorophenoxy Acetic Acid • 4,4-Ddd • 4,4-Dde • 4,4-Ddt • Abamectin • Acephate • Alachlor • Aldicarb • Aldrin • Ametryn • Aminopyralid • Amitraz • Ampa • Asulam • Atrazine • Atrazine-Desethyl • Atrazine-Desisopropyl • Azinphos-Ethyl • Azinphos-Methyl • Azoxystrobin • Bendiocarb • Benomyl • Bensulfuron Methyl • Bensulide • Bentazon • BHC (Alpha)
Mirboo North	Little Morwell River			
Moe	Tanjil River and Narracan Creek		<u>Metals</u> <ul style="list-style-type: none"> • Aluminium Total • Arsenic Total • Calcium Total • Cadmium Total • Copper Total • Iron Total • Iron Soluble • Lead Total • Mercury • Potassium • Magnesium • Manganese Total • Manganese Soluble • Selenium • Zinc Total 	
Newborough				
Yallourn North				
Trafalgar				
Yarragon				
Neerim South		Tarago River		
Noojee				
Sale/Wurruk	Bore (Boisdale Aquifer)		<u>PFOS/PFOA suite (Seaspray, Sale Bores, Briagolong Bores and reticulation)</u>	
Seaspray	Merrimans Creek			
Thorpdale	Easterbrook Creek			
Willow Grove	Tanjil River			

Locality	Source water	Nature of other raw water monitoring programs		
		Weekly/Fortnightly	Monthly	Annual/Quarterly
				<ul style="list-style-type: none"> • BHC (Beta) • BHC (Delta) • Bifenthrin • Boscalid • Brodifacoum • Bromacil • Bromophos-Ethyl • Bromoxynil • Butachlor • Carbaryl • Carbendazim • Carbofenthion • Carbofuran • Carboxin • Carfentrazone-Ethyl • Chlorantraniliprole • Chlordane (Cis) • Chlordane (Trans) • Chlorfenvinphos • Chlorothalonil • Chloroxuron • Chlorpyrifos • Chlorpyrifos - Methyl • Chlorsulfuron • Clopyralid • Coumaphos • Cyanazine • Cyfluthrin • Cypermethrin • Cyproconazole • Cyprodinil • Cypromazine • Cyromazine • Deltamethrin • Demeton-O • Demeton-S • Demeton-S-Methyl • Diazinon

Locality	Source water	Nature of other raw water monitoring programs		
		Weekly/Fortnightly	Monthly	Annual/Quarterly
				<ul style="list-style-type: none"> • Dicamba • Dichlobenil • Dichlorprop • Dichlorprop-P • Dichlorvos • Diclofop-Methyl • Dicofol • Dieldrin • Difenoconazole • Diflubenzuron • Diflufenican • Dimethoate • Dinoseb • Diphenamid • Diquat • Disulfoton • Diuron • ENDOSULFAN (Alpha) • ENDOSULFAN (Beta) • Endosulfan Sulphate • Endothal • Endrin • Endrin Aldehyde • Endrin Ketone • Epn • Eptc • Ethion • Ethoprophos • Etridiazole • Fenamiphos • Fenarimol • Fenchlorphos (Ronnel) • Fenitrothion • Fenoxycarb • Fensulfothion • Fenthion • Fenvalerate • Fipronil

Locality	Source water	Nature of other raw water monitoring programs		
		Weekly/Fortnightly	Monthly	Annual/Quarterly
				<ul style="list-style-type: none"> • Flamprop Methyl • Fluometuron • Flupropanate • Fluroxypyr • Flusilazole • Formothion • Fosetyl Aluminium • Glyphosate • Haloxyfop • Heptachlor • Heptachlor Epoxide • Hexachlorobenzene • Hexaconazole • Hexaflurate • Hexazinone • Imazapyr • Indoxacarb • Iodosulfuron Methyl • Iprodione • Irgarol • Isoproturon • Lindane • Malathion • Mcpa • Mcpb • Mecoprop • Metalaxyl • Metalaxyl-M • Metaldehyde • Methidathion • Methiocarb • Methomyl • Methoxychlor • Metolachlor • Metribuzin • Mevinphos • Molinate • Monocrotophos

Locality	Source water	Nature of other raw water monitoring programs		
		Weekly/Fortnightly	Monthly	Annual/Quarterly
				<ul style="list-style-type: none"> • Myclobutanil • Naftalofos • Napropamide • Nicarbazin • Nitralin • Norfluazon • Novaluron • Omethoate • Oryzalin • Oxamyl • Oxychlordane • Oxyfluorfen • Paclobutrazole • Paraquat • Parathion • Parathion-Methyl • Pebulate • Penconazole • Pendimethalin • Permethrin • Pfas • Phorate • Picloram • Pirimicarb • Pirimiphos-Ethyl • Pirimiphos-Methyl • Prochloraz • Profenofos • Promecarb • Prometon • Prometryn • Propachlor • Propamocarb • Propanil • Propargite • Propazine • Propiconazole • Propyzamide

Locality	Source water	Nature of other raw water monitoring programs		
		Weekly/Fortnightly	Monthly	Annual/Quarterly
				<ul style="list-style-type: none"> • Prothiofos • Pyraclostrobin • Pyrasulfatole • Pyrazophos • Pyrimethanil • Pyriproxyfen • Pyroxsulam • Quinclorac • Rimsulfuron • Siduron • Silvex • Simazine • Simetryn • Spirotetramat • Sulfotep • Sulprofos • Tebuconazole • Tebuthiuron • Temephos • Terbacil • Terbufos • Terbutylazine • Terbutryn • Tertbutryn • Tetrachlorvinphos • Tetraconazole • Thiamethoxam • Thiobencarb • Thiodicarb • Thiometon • Toltrazuril • Trans Chlordane • Triadimefon • Triadimenol • Triazophos • Trichlorfon • Trichloronate • Triclopyr

Locality	Source water	Nature of other raw water monitoring programs		
		Weekly/Fortnightly	Monthly	Annual/Quarterly
				<ul style="list-style-type: none"> • Trifloxystrobin • Trifloxysulfuron-Sodium • Trifluralin • Trinexapac Ethyl • Vernolate

*Reduced frequency of monitoring in some catchments based on risk profile.

** Note all pesticides, herbicides and chemical organics results were within ADWG guideline values.

Not all parameters were measured at all localities or source waters.

Purpose of monitoring - risk management within catchments and raw water supply systems.

Comprehensiveness (frequency) – weekly, fortnightly, monthly, quarterly and annual monitoring or as risks identified.

APPENDIX 2: SAFE DRINKING WATER ACT AUDIT CERTIFICATE OF COMPLIANCE

Schedule 1


Risk management plan audit certificate

Safe Drinking Water Regulations 2015 - Regulation 10

Certificate Number: 150
Audit period: 10 June 2016 to 30 May 2018
To: Lynley Keene,
Manager, Governance
Gippsland Water
PO Box 348
Traralgon, Vic, 3844
Australian Business Number (ABN): 75 830 750 413

I, Robert Burford, after conducting a risk management plan audit of the water supplied by Gippsland Water, am of the opinion that—

Gippsland Water has complied with the obligations imposed by section 7(1) of the *Safe Drinking Water Act 2003* during the audit period.



Signature of approved auditor:

Date: 30 May 2018.



Gippsland Water

PO BOX 348
55 Hazelwood Road
Traralgon VIC 3844

Enquiries 1800 050 500
Faults and emergencies 1800 057 057

contactus@gippswater.com.au
www.gippswater.com.au

ABN 75 830 750 413

