



NOTES:
1. RATINGS CHANGE WITH THE SIZE OF THE PUMP STATION
REFER TO DRAWING A1-52794 FOR THESE FUSE &
CIRCUIT BREAKER RATINGS.

REV	No.	DATE	DESCRIPTION	APP'D	REFERENCES	PLAN No.	TITLE
4	27/9/21		CHANGE GENERATOR POINT FROM SOCKET TO PLUG.	P.S.			
3	7/9/20		UPDATED DRAWING SHEETS MAIN SWITCH REPLACED BY MCCBS.	P.S.			
2	25/10/13		REVISED NOTE 1 DETAILS.	P.J.			
1	18/3/13		REMOVED EARTH FROM SUPPLY AUTHORITY 415V SUPPLY.	P.J.			
0	24/9/12		INITIAL ISSUE.	P.J.			

DESIGNED BY:

OPTIMUM
DRAFTING PTY LTD
A.B.N. 28 065 272 942

DO NOT SCALE

GIPPSLAND WATER
DRAWING STATUS

STANDARD DRAWING

GIPPSLAND WATER FACILITY CODE
XXCPXX

DRAWING No.
A1-52773

REV.
4

CERTIFICATION OF
COMPLIANCE WITH
GIPPSLAND WATER'S
DESIGN & DRAFTING
REQUIREMENTS.

DESIGNED:
25/01/2018 - STD DRG

DRAWN:
25/01/2018 - OPT/CT

CHECKED:
25/01/2018 - P STEWART

STANDARD SEWERAGE PUMP STATION
PUMP STATION 30kW TO 160kW (VSD) - CT METERED
MAIN DISTBN COMPT - POWER & CONTROL SUPPLIES
ELECTRICAL SCHEMATIC DIAGRAM - SHEET 1 OF 3