



PLATE IN CUBICLE
FOR MOUNTING FUSES

FUSES

OUTLINE OF
DOOR OPENING

400A CT CHAMBER

BUSBAR: 1 - 40mm X 10mm Cu BUSBAR PER PHASE

CT'S: ESAA TYPE B

FUSES: 3 - 32A FUSE HOLDER c/w 32A FUSE LINK

REVISIONS	No.	DATE	DESCRIPTION	APP'D
	1	7/9/20	UPDATED DRAWING SHEETS.	P.S.
	0	24/9/12	INITIAL ISSUE.	P.J.

REFERENCES	PLAN No.	TITLE
	A1-52770	STD SPS - PUMP STN 30kW TO 160kW (VSD) - CT METERED - I & C - DRG INDEX

DESIGNED BY:



DO NOT SCALE	GIPPSLAND WATER DRAWING STATUS	STANDARD DRAWING	GIPPSLAND WATER FACILITY CODE XXCPXX
CERTIFICATION OF COMPLIANCE WITH GIPPSLAND WATER'S DESIGN & DRAFTING REQUIREMENTS.		DRAWING No. A1-52802	
DESIGNED: 25/01/2018 - STD DRG		REV. 1	
DRAWN: 25/01/2018 - OPT/CT		STANDARD SEWERAGE PUMP STATION PUMP STATION 30kW TO 160kW (VSD) - CT METERED SUPPLY CUBICLE	
CHECKED: 25/01/2018 - P STEWART		400A CT GEAR TRAY LAYOUT	