



- NOTES:
1. MAIN SWITCH TOP HAT  
REFER A1-52811 FOR DETAILS
  2. CT TOP HAT  
REFER A1-52811 FOR DETAILS
  3. DISTRIBUTION BOARD 1 TOP HAT  
REFER A1-52811 FOR DETAILS
  4. DISTRIBUTION BOARD 2 MAIN SWITCH TOP HAT  
REFER A1-52811 FOR DETAILS
  5. DISTRIBUTION BOARD 2 TOP HAT  
REFER A1-52811 FOR DETAILS
  6. BARE CONNECTIONS NOT OTHERWISE SHROUDED OR PROTECTED FROM  
PHYSICAL CONTACT SHALL BE COVERED WITH HEATSHRINK OR SIMILAR

REVISIONS	No.	DATE	DESCRIPTION	APP'D	REFERENCES	PLAN No.	TITLE
	3	18/5/21	SCOMEK SWITCH CHANGED TO 4 POLE.	P.S.			
	2	7/9/20	UPDATED DRAWING SHEETS.	P.S.			
	1	9/10/13	REVISED DRAWING.	M.B.			
	0	24/9/12	INITIAL ISSUE.	P.J.			
					A1-52770	STD SPS - PUMP STN 30kW TO 160kW (VSD) - CT METERED - I & C - DRG INDEX	

DESIGNED BY:

**OPTIMUM**  
DRAFTING PTY LTD  
A.B.N. 28 065 272 942

DO NOT SCALE	GIPPSLAND WATER DRAWING STATUS	STANDARD DRAWING	GIPPSLAND WATER FACILITY CODE XXCPXX
CERTIFICATION OF COMPLIANCE WITH GIPPSLAND WATER'S DESIGN & DRAFTING REQUIREMENTS.	DRAWING No. A1-52809	REV. 3	
DESIGNED: 25/01/2018 - STD DRG	STANDARD SEWERAGE PUMP STATION PUMP STATION 30kW TO 160kW (VSD) - CT METERED SUPPLY CUBICLE - MAIN DISTRIBUTION GEAR TRAY & ESCUTCHEON DOOR LAYOUT - 45kW - SHEET 1 OF 3		
DRAWN: 25/01/2018 - OPT/CT			
CHECKED: 25/01/2018 - P STEWART			