



250A CT CHAMBER

- BUSBAR: 1 - 30mm X 10mm Cu BUSBAR PER PHASE
- CT'S: ESAA TYPE S
- FUSES: 3 - 32A FUSE HOLDER c/w 32A FUSE LINK

REVISIONS					REFERENCES			DESIGNED BY:	<div><div></div><div>OPTIMUM DRAFTING PTY LTD A.B.N. 28 065 272 942</div></div>	DO NOT SCALE	GIPPSLAND WATER DRAWING STATUS	STANDARD DRAWING	GIPPSLAND WATER FACILITY CODE XXCPXX
											DRAWING No. A1-52801	REV. 1	
	1	7/9/20	UPDATED DRAWING SHEETS.	P.S.									
	0	24/9/12	INITIAL ISSUE.	P.J.		A1-52770	STD SPS - PUMP STN 30kW TO 160kW (VSD) - CT METERED - I & C - DRG INDEX						
	No.	DATE	DESCRIPTION	APP'D		PLAN No.	TITLE						

CERTIFICATION OF COMPLIANCE WITH GIPPSLAND WATER'S DESIGN & DRAFTING REQUIREMENTS.	DESIGNED: 25/01/2018 - STD DRG	DRAWN: 25/01/2018 - OPT/CT	CHECKED: 25/01/2018 - P STEWART
	STANDARD SEWERAGE PUMP STATION PUMP STATION 30kW TO 160kW (VSD) - CT METERED SUPPLY CUBICLE 250A CT GEAR TRAY LAYOUT		