



19	VALVE SPINDLE	1 (2)	STAINLESS STEEL	A1-70488	TO BE USED ON OVERFLOW IF REQUIRED	40	INTERMEDIATE PUMP GUIDE RAIL SUPPORT	1	STAINLESS STEEL	-	-
18	(100/150) THRUST TYPE DISMANTLING JOINT	3	STAINLESS STEEL	A1-53173	-	39	(225 - 300) DUCKBILL CHECK VALVE	1	STAINLESS STEEL	-	-
17	(150 - 300) KNIFE GATE VALVE FL-FL (NON RISING SPINDLE)	1	STAINLESS STEEL	WB14E	-	38	(225 - 300) PIPE SPOOL C/W PN16 FLANGE ONE END & PUDDLE FLANGE TO SUIT	1	STAINLESS STEEL	-	-
16	SPOOL	2	STAINLESS STEEL	A1-70480	-	37	(225 - 300) VARI-GIB TO SUIT	1	STAINLESS STEEL	-	-
15a	Ø150 BLANK FLANGE	1	AS SUPPLIED	-	-	36	(150 - 300) DROP PIPE TO SUIT	1	STAINLESS STEEL	-	-
15	Ø150 RESILIENT SEATED STOP VALVE FL-FL	1	AS SUPPLIED	-	-	35	(150 - 300) PIPE SPOOL C/W PN16 FLANGE ONE END & PUDDLE FLANGE TO SUIT	1	STAINLESS STEEL	-	-
14	SPOOL	1	STAINLESS STEEL	A1-70480	-	34	(150 - 300) VARI-GIB TO SUIT	1	STAINLESS STEEL	-	-
13	(100/150) FLOW METER	1	AS SUPPLIED	-	-	33	20 BSP VALVE	2	STAINLESS STEEL	-	-
12	SPOOL	1	STAINLESS STEEL	A1-70480	-	32	20 BSP MALE - MALE NIPPLE	2	STAINLESS STEEL	-	-
11	SPOOL	1	STAINLESS STEEL	A1-70480	-	31	SPOOL	2	STAINLESS STEEL	A1-70480	-
10	SPOOL	2	STAINLESS STEEL	A1-70480	-	30	80mm PVC DRAIN WITH FLAP VALVE	1	AS SUPPLIED	-	-
9	(100/150) RESILIENT SEATED STOP VALVE FL-FL C/W EXTENSION SPINDLE	3	AS SUPPLIED	-	-	29	FLOAT SWITCH	3	AS SUPPLIED	-	-
8	(100/150) NON RETURN BALL VALVE FL-FL	2	AS SUPPLIED	-	-	28	MJK ULTRASONIC LEVEL SENSOR	1	AS SUPPLIED	-	-
7	SPOOL	2	STAINLESS STEEL	A1-70480	-	27	SPARE	-	-	-	-
6	UPPER GUIDE RAIL RETAINER	2	STAINLESS STEEL	-	PART No. SC-11-490034	26	RISER PIPE SUPPORT BRACKET	4	STAINLESS STEEL	A1-70491	-
5	PUMP GUIDE RAIL (TO SUIT)	2	STAINLESS STEEL	-	-	25	(100/150) 45° BEND FL-FL	2	DIEL	-	-
4	SPOOL	1	STAINLESS STEEL	A1-70480	-	24	WET WELL WASHER BRACKET	1	STAINLESS STEEL	A1-70492	-
3	SPOOL	1	STAINLESS STEEL	A1-70480	-	23	PIPE STAND (ADJUSTABLE)	2	STAINLESS STEEL	-	-
2	(100/80) DISCHARGE PEDESTAL	2	AS SUPPLIED	-	-	22	(100/150) SPOOL	1	STAINLESS STEEL	-	-
1	SUBMERSIBLE PUMP FLYGT (IMP300S, 103 SH 126 DIA) IMPELLER WITH SCREENED CABLE OR APPROVED EQUIVALENT	2	AS SUPPLIED	-	-	21	LEVEL SENSOR BRACKET	1	STAINLESS STEEL	A1-70493	-
						20	(225 - 300) KNIFE GATE VALVE FL-FL (NON RISING SPINDLE) TO SUIT OVERFLOW (IF REQUIRED)	1	STAINLESS STEEL	-	WB14E

GENERAL ARRANGEMENT

NOTE:
PARTS SHOWN IN RED DASH POSITION & ROTATION TO BE DETERMINED WITH INITIAL DESIGN.

REMOVE THIS NOTE UPON DRAWINGS BEING FINALISED.

ALL DIMENSIONS SHOWN "X" TO BE REPLACED WITH ACTUAL DIMENSION PRIOR TO FINAL DESIGN

PIPEWORK AND FITTING NOTES REFER DRG. A1-70472

REVISIONS	No.	DATE	DESCRIPTION	APP'D
	0	28/06/2	INITIAL ISSUE	GM

REFERENCES	PLAN No.	DRAWING INDEX	TITLE
	A1-70478	(ICAD MASTER FILE)	
	A1-70471	DRAWING INDEX	

DESIGNED BY:	

DO NOT SCALE

CERTIFICATION OF COMPLIANCE WITH GIPPSLAND WATER'S DESIGN & DRAFTING REQUIREMENTS.
DESIGNED: / /
DRAWN: 13/02/19 GM
CHECKED: 09/04/21 RD/FR

GIPPSLAND WATER
"LOCATION" SEWER RETICULATION
SEWAGE PUMP STATION
MECHANICAL & PIPEWORK FIT-OUT
GENERAL ARRANGEMENT & ITEM LIST

DRAWING No. A1-70478
REV. 0

TBD