



NOTES FOR LOCATION OF PUMP CONTROL CUBICLE

- DOORS TO HINGE AWAY FROM WELL.
- CUBICLE TO BE LOCATED TO ALLOW ACCESS TO CONTROLS SAFELY WHEN WELL COVERS ARE OPEN.
- WELL COVERS TO BE HINGED SO COVERS CAN BE OPENED FULLY WITHOUT COMING INTO CONTACT ELECTRICAL CUBICLE.

SECTION "B-B"

| REVISIONS | | | | | | REFERENCES | | |
|-----------|-----|---------|-------------------------------------|-------|--|------------|----------|---|
| | | | | | | | | |
| | | | | | | | | |
| | 8 | 12/7/17 | REDRAWN IN DGN & GENERAL REVISIONS. | P.S. | | | A1-47731 | STANDARD SPS - PUMP STATION UP TO 5.5kw (DOL) - I & C - DRAWING INDEX |
| | No. | DATE | DESCRIPTION | APP'D | | | PLAN No. | TITLE |

DESIGNED BY:

OPTIMUM
DRAFTING PTY LTD
A.B.N. 28 065 272 942

| | | | |
|---|-----------------------------------|---|--|
| DO NOT SCALE | GIPPSLAND WATER DRAWING STATUS | STANDARD DRAWING | GIPPSLAND WATER FACILITY CODE XXCPXX |
| CERTIFICATION OF COMPLIANCE WITH GIPPSLAND WATER'S DESIGN & DRAFTING REQUIREMENTS. DESIGNED: 12/07/2017 - STD DRG DRAWN: 12/07/2017 - OPT/RJ CHECKED: 19/07/2017 - P STEWART | | GIPPSLAND WATER STANDARD SEWERAGE PUMP STATION PUMP STATION UP TO 5.5kw (DOL) BACK TO BACK CUBICLE PUMP WELL DETAILS | |
| | | DRAWING No. A1-47768 | REV. 8 |