



REV	No.	DATE	DESCRIPTION	APP'D	REFERENCES	PLAN No.	TITLE
	12	10/11/20	REVISED RSIR TO LSIR & ADDED FLOAT CONTROL INHIBIT.	P.S.			
	11	16/11/17	CHANGED RTUFR CONTACT NC TO NO ADDED REMOTE START INHIBIT RELAY.	G.F.			
	10	17/7/17	REDRAWN IN DGN & GENERAL REVISION.	P.S.	A1-47731	STANDARD SPS PUMP STATION UP TO 5.5kW (DOL) - I & C - DRAWING INDEX	

DESIGNED BY:

DESIGNER'S CERTIFICATION

OPTIMUM
DRAFTING PTY LTD
A.B.N. 28 065 272 942

CERTIFICATION OF
COMPLIANCE WITH
GIPPSLAND WATER'S
DESIGN & DRAFTING
REQUIREMENTS.

DESIGNED:
12/07/2017 - STD DRG

DRAWN:
22/07/2010 - OPT/RJ

CHECKED:
19/07/2017 - P STEWART

GIPPSLAND WATER

STANDARD SEWERAGE PUMP STATION
PUMP STATION UP TO 5.5kW (DOL)
'ACE3600' TELEMETRY SLOT 1 - MIXED I/O CARD
ELECTRICAL SCHEMATIC DIAGRAM - SHEET 2 OF 2

DO NOT SCALE

GIPPSLAND WATER
DRAWING STATUS

STANDARD DRAWING

GIPPSLAND WATER FACILITY CODE
XXCPXX

REV.

DRAWING No.

A1-47741

12