

NOTE 1
RATINGS CHANGE WITH THE SIZE OF THE PUMP STATION.
REFER TO DRG A1-48317 FOR THE MAIN SWITCH & CB RATINGS.

REVISIONS				REFERENCES			
No.	DATE	DESCRIPTION	APP'D	PLAN No.	TITLE		
13	9/11/18	CHANGED PHASE FAILURE RELAY (PFR) TYPE.	G.F.				
12	16/11/17	CHANGED SURGE DIVERTER TYPE.	G.F.				
11	17/7/17	REDRAWN IN DGN & REVISED CHANGEOVER SWITCH.	P.S.				
				A1-47731	STANDARD SPS PUMP STATION UP TO 5.5kW (DOL) - I & C - DRAWING INDEX		

DESIGNED BY:



OPTIMUM
DRAFTING PTY LTD
A.B.N. 28 065 272 942

DO NOT SCALE

GIPPSLAND WATER
DRAWING STATUS


STANDARD DRAWING

GIPPSLAND WATER FACILITY CODE
XXCPXX

DRAWING No.
A1-47733

REV.
13

CERTIFICATION OF COMPLIANCE WITH GIPPSLAND WATER'S DESIGN & DRAFTING REQUIREMENTS.
DESIGNED: 12/07/2017 - STD DRG
DRAWN: 22/07/2010 - OPT/RJ
CHECKED: 19/07/2017 - P STEWART



STANDARD SEWERAGE PUMP STATION
PUMP STATION UP TO 5.5kW (DOL)
POWER & CONTROL SUPPLIES
ELECTRICAL SCHEMATIC DIAGRAM - SHEET 1 OF 2