





<u>MATERIAL:</u>	3.0mm MARINE GRADE ALUMINIUM.
<u>FINISH:</u>	TO BE POWDER COATED COLORBOND WILDERNESS GREEN.
<u>HINGES:</u>	GRADE 316 STAINLESS STEEL HINGES & PINS WITH LOCKING WASHERS UNDER FIXING SCREWS.
<u>HANDLES:</u>	TO BE SUPPLIED BY CLIENT REQUIRE 3 POINT LOCKING SYSTEM WITH ROLLER ENDS TO BE SUPPLIED BY MANUFACTURER ON DOORS. ALL LOCKS ARE SY3.
<u>GEAR PLATES:</u>	CONTROL & DISTRIBUTION GEAR TRAY - 1020mm HIGH x 910mm WIDE TELEMETRY GEAR TRAY - 620mm HIGH x 880mm WIDE INSTRUMENT GEAR TRAY - 400mm HIGH x 400mm WIDE TO BE POWDER COATED WHITE & FRONT OF GEAR TRAY TO BE 25mm FROM WALL.
<u>ESCUTCHEON DOORS:</u>	TO BE POWDER COATED WHITE & HAVE M4 CHROMED, SLOTTED ROUND HEAD THUMB SCREWS WITH RETAINING CLIP (2 PLACES). TO BE FITTED WITH CABLE SUPPORT RAILS MOUNTED BEHIND.
<u>EXTERNAL VENTS:</u>	B & R EXTERNAL VENT KIT IPVK SUFFICIENT WITH GASKET, INSERT FILTER & FIXINGS OR EQUIVALENT.
<u>PLINTH:</u>	ALUMINIUM PREFORMED CHANNEL CONSTRUCTED IN ONE CONTINUOUS LENGTH.
<u>DOOR SEALS:</u>	5060 PVC / NITRILE 6mm THICK OR EQUIVALENT.
<u>DOOR STAYS:</u>	ALL EXTERNAL DOORS TO BE FITTED WITH MECHANICALLY LOCKING ROD TYPE DOOR STAYS TO KEEP DOOR OPEN AT A MINIMUM OF 110 DEGREES.
<u>CABLE SUPPORTS:</u>	10 x 25 CABLE SUPPORT RAILS TO BE MOUNTED ON SIDE OF CABINET'S INTERIOR & ESCUTCHEON AS SHOWN.

REVISIONS					REFERENCES		
	11	16/11/17	MOVED SECTION E-E ARROWS DOWN.	G.F.			
	10	12/7/17	REVISED FOR NEW CHANGEDOVER SWITCH & PROCONNECT PLUG.	P.S.		A1-47731	STANDARD SPS - PUMP STATION UP TO 5.5kW (DOL) - I & C - DRAWING INDEX
	No.	DATE	DESCRIPTION	APP'D		PLAN No.	TITLE

OPTIMUM
RAFTING PTY LTD
A.B.N. 28 065 272 942

DO NOT SCALE	GIPPSLAND WATER DRAWING STATUS	STANDARD DRAWING	GIPPSLAND WATER FACILITY CODE XXCPXX
CERTIFICATION OF COMPLIANCE WITH GIPPSLAND WATER'S DESIGN & DRAFTING REQUIREMENTS.	 GIPPSLAND WATER		DRAWING No. A1-48310
DESIGNED: 12/07/2017 - STD DRG	 STANDARD SEWERAGE PUMP STATION PUMP STATION UP TO 5.5kW (DOL) BACK TO BACK CUBICLE GENERAL ARRANGEMENT		
DRAWN: 12/07/2017 - OPT/RJ			
CHECKED: 19/07/2017 - P STEWART			
			REV. 11